

FGE



July 9, 1980
CPY-617-80

Mr. R. H. Engelken, Director
Nuclear Regulatory Commission
1990 North California Blvd.
Walnut Creek, California 94596

Dear Sir:

Subject: Immediate Report of Reportable Occurrence

This letter is a followup to a report made by W. S. Orser, Manager of Operations and Maintenance to Gary Johnston, NRC Resident Inspector at 9:00 a.m. on Wednesday, July 9, 1980, concerning a situation where a violation of the Trojan Plant Environmental Technical Specifications occurred. Residual chlorine and pH readings were out of specification for approximately eleven minutes. The highest value of residual chlorine measured was 4 ppm; the lowest pH measurement was 4.5. The apparent cause of this occurrence was operator error.

This occurrence will be reported to the Nuclear Regulatory Commission as a Licensee Event Report in accordance with our established Technical Specifications.

Sincerely,

C. P. Yundt
C. P. Yundt
General Manager

CPY
CPY/WSO:na

c: LER Distribution

0003
S 1/0