

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NYJAFI 200-0000-0000 341111 4 5
7 8 9 14 15 25 26 30 57 CAT 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T
 01 REPORT SOURCE L 605000333 7062880 8072280 9
7 8 60 61 68 69 74 75 80
 DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal shutdown, while conducting surveillance required by TS 4.12.A.1.1 one
 03 (1) cell in each 24 volt battery for the Diesel Fire Pump failed to meet the minimum
 04 specific gravity requirements of the surveillance test. Cell A2-6 read 1.243 and cell
 05 B2-1 read 1.246 compared to a minimum of 1.2. The engine was test started with
 06 satisfactory results. The event did not represent a significant hazard to the
 07 public health and safety.

08 _____ 9

09 SYSTEM CODE AB 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE Z Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 18 19 20
 LER/RO REPORT NUMBER 17 80 21 22 SEQUENTIAL REPORT NO. 057 24 25 OCCURRENCE CODE 03 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32
 ACTION TAKEN X 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0000 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z999 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The low specific gravity was the result of the charger being out of service while
 11 surveillance required by TS 4.12.A.1.j was being performed. Following a battery
 12 charge, satisfactory specific gravities were obtained. No additional action is
 13 required.

14 _____ 9

15 FACILITY STATUS G 28 % POWER 0000 29 OTHER STATUS NA 30 METHOD OF DISCOVERY b 31 DISCOVERY DESCRIPTION Surveillance Test 32
7 8 9 10 12 13 44 45 46 80
 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 44 45 80
 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 11 12 13 80
 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION NA 41
7 8 9 11 12 80
 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 FACILITY DESCRIPTION NA 43
7 8 9 10 80
 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

NRC USE ONLY

20 NAME OF PREPARER W. Verne Childs PHONE 315-342-3840
7 8 9 68 69 80

80 0722 369