



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TJC

JUN 16 1980

State of Illinois  
Department of Public Health  
ATTN: Mr. Gary N. Wright, Chief  
Division of Nuclear Safety  
535 West Jefferson Street  
Springfield, IL 62761

Gentlemen:

The enclosed IE Information Notice No. 80-28 titled "Prompt Reporting of Information in Accordance with 10 CFR 50.55(e)" was sent to the following licensees on June 13, 1980.

Cincinnati Gas and Electric Company  
Zimmer (50-358)

Cleveland Electric Illuminating Company  
Perry 1, 2 (50-440, 50-441)

Commonwealth Edison Company  
Braidwood 1, 2 (50-456, 50-457)  
Byron 1, 2 (50-454, 50-455)  
La Salle 1, 2 (50-373, 50-374)

Consumers Power Company  
Midland 1, 2 (50-329, 50-330)

Detroit Edison Company  
Fermi 2 (50-341)

Illinois Power Company  
Clinton 1, 2 (50-461, 50-462)

Northern Indiana Public Service Company  
Bailly (50-367)

Public Service of Indiana  
Marble Hill 1, 2 (50-546, 50-547)

8007290 104


State of Illinois

- 2 -

JUN 16 1980

Union Electric Company  
Callaway 1, 2 (50-483, 50-486)

Sincerely,



Helen Pappas, Chief  
Administrative Branch

Enclosure: IE Information  
Notice No. 80-28

cc w/encl:  
Mr. D. W. Kane,  
Sargent & Lundy  
Central Files  
Reproduction Unit NRC 20b  
Local PDR  
NSIC  
TIC

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

SSINS No.: 6835  
Accession No.:  
8005050063

June 13, 1980

IE Information Notice No. 80-28

PROMPT REPORTING OF INFORMATION IN ACCORDANCE WITH 10 CFR 50.55(e)

The recently implemented expansion of the NRC Resident Inspection Program at nuclear power plants and fuel facilities, has led to some misunderstandings regarding the required reporting of information to the NRC. In order to clarify this matter, the following is provided for your information.

Some licensees have been making the 24 hour reports required by 10 CFR 50.55(e)(2) orally to NRC resident inspectors. This does not satisfy either the letter or the intent of the regulation. Adherence by all licensees to the explicit requirements of the regulation provides, for each Regional Office to be the single focal point for reporting, and minimizes the possibility of inadvertent oversight. While we continue to enlist your cooperation in fully informing our resident inspectors, where appropriate, or any other NRC inspector who may be at your facility at such a time, such informational exchanges do not satisfy the reporting requirements of 10 CFR 50.55(e)(2).

Your cooperation in assuring that the appropriate members of your staff are fully aware of this information will be appreciated.

No written response to this information notice is required. If you require additional information regarding this matter contact the Director of the appropriate NRC Regional Office.

IE Information Notice No. 80-28  
June 13, 1980

Enclosure

RECENTLY ISSUED  
IE INFORMATION NOTICES

Information Notice No.	Subject	Date Issued	Issued To
80-27	Degradation of Reactor Coolant Pump Studs	6/11/80	All Pressurized Water Reactor Facilities holding power reactor OLs or CPs
80-26	Evaluation of Contractor QA Programs	6/10/80	All Part 50 Licensees
80-25	Transportation of Pyrophoric Uranium	5/30/80	Material Licensee in Priority/Categories II-A, II-D, III-I and IV-DI; Agreement State Licensees in equivalent categories
80-24	Low Level Radioactive Waste Burial Criteria	5/30/80	All NRC and Agreement State Licensees
80-23	Loss of Suction to Emergency Feedwater Pumps	5/29/80	All power reactor facilities with an OL or CP
80-22	Breakdown In Contamination Control Programs	5/28/80	All power reactor OLs and near term CPs
80-21	Anchorage and Support of Safety-Related Electrical Equipment	5/16/80	All power reactor facilities with an OL or CP
80-20	Loss of Decay Heat Removal Capability at Davis-Besse Unit 1 While in a Refueling Mode	5/8/80	All light water reactor facilities holding power reactor OLs or CPs
80-19	NIOSH Recall of Recirculating-Mode (Closed-Circuit) Self-Contained Breathing Apparatus (Rebreathers)	5/6/80	All holders of a power reactor OL, Research Reactor License, Fuel Cycle Facility License and Priority I Material License