

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
1750 Chestnut Street Tower II

July 18, 1980

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE
REPORT BPRO-50-259/8054

The enclosed report provides details concerning the peak river temperature
of 90.2°F. This report is submitted in accordance with Browns Ferry
unit 1 Environmental Technical Specification Appendix B 5.6.3.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. R. Calhoun
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Lavallee
Nuclear Safety Analysis Center
Palo Alto, California 94303

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

A002
S
1/1

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

8007290657