

LER SUPPLEMENTAL INFORMATION

BFRO-50- 259 / 80 54 Technical Specification Involved ETS 2.1
Reported Under Technical Specification ETS 5.6.3.b
Date of Occurrence 7/6/80 Time of Occurrence 1645 Unit 0

Identification and Description of Occurrence:

Peak river temperature of 90.2 degrees F. was reached prior to the temperature decline starting as a result of corrective action initiated based on river temperature predictions.

Conditions Prior to Occurrence:

Unit 1 @ 84.6% MWe

Unit 2 @ 97.3% MWe

Unit 3 @ 0% MWe

Action specified in the Technical Specification Surveillance Requirements met due to inoperable equipment. Describe.

Reduced waste heat discharge to the reservoir.

Apparent Cause of Occurrence:

Computer predictions of river temperature was inaccurate due to solar heating.

Analysis of Occurrence:

There was no damage to the plant equipment. There was no activity released, no personnel exposure or injury and no danger to the health or safety of the public.

Corrective Action:

U-1 and 2 placed on cooling towers. U-1 load reduced 125 MWe.

Failure Data:

None

*Retention: Period - Lifetime; Responsibility - Administrative Supervisor

*Revision: 