

NSP

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

July 24, 1980

Mr J G Keppler
Office of Inspection & Enforcement
U S Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr Keppler:

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket No. 50-282 License No. DPR-42

Power Range High Power Trip Setpoint Set Slightly Above
the Technical Specification Limit of 108%

The Licensee Event Report for this occurrence is reproduced on the back of this letter. Enclosed are three copies.

This event is reported in compliance with Technical Specification 6.7.B.2 (a) in that it represents an instrument setting less conservative than that required by the Technical Specifications, but which would not have prevented meeting the functional requirements of the reactor protection system.

Yours very truly,

David M. Mayer

L O Mayer, PE
Manager of Nuclear Support Services

LOM/DMM/jh

cc: Director, IE, USNRC (30)
Director, MIPC, USNRC (3)
MPCA
Attn: J W Ferman

-over-

8007290 669