NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | T | N | S | N | P | 1 | (2) | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | (3) | 4 | 1 | 1 | 1 | 1 | (4) | | | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT 58

CON'T
01 REPORT SOURCE | L | (6) | 0 | 5 | 0 | 0 | 0 | 3 | 2 | 7 | (7) | 0 | 6 | 2 | 4 | 8 | 0 | (8) | 0 | 7 | 2 | 3 | 8 | 0 | (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During normal operation a fuse in the switching bridge circuit
03 | failed on vital inverter 2-I which rendered the 120 volt a.c. vital
04 | instrument power board 2-I inoperable. This resulted in entering
05 | the action statement of LCO 3.8.2.1.
06 |
07 |
08 |

09 | SYSTEM CODE: E C (11) | CAUSE CODE: X (12) | CAUSE SUBCODE: Z (13) | COMPONENT CODE: C K T B R K (14) | COMP. SUBCODE: X (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 0 | -- | 1 0 8 | -1 | 0 3 | L | -- | 0
SEQUENTIAL REPORT — OCCURRENCE CODE — REPORT TYPE — REVISION NO.

ACTION TAKEN: A (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORMS: N (24) | PRIME COMPONENT MANUFACTURER: N (25) | X 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTION (27)

11 | The fuse was replaced and the system was declared operable. The
12 | cause of the initial fuse failure is unknown.
13 |
14 |

15 | FACILITY STATUS: B (28) | POWER: 0 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): Operator Observation

16 | ACTIVITY CONTENT: RELEASED OR RELEASE: Z (33) | Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

17 | PERSONNEL EXPOSURES: NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

18 | PERSONNEL INJURIES: NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

19 | LOSS OF OR DAMAGE TO FACILITY (43): TYPE: Z (42) | DESCRIPTION: NA

20 | PUBLICITY: ISSUED (44) | DESCRIPTION (45): N (44) NA | NRC USE ONLY

NAME OF PREPARER: Dean Romine PHONE:

8007290770

POOR ORIGINAL