



UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION IV
811 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76012

VIA AIR MAIL

24 MAR 1980

Docket No. 99900039/79-02

Rhine-Schelde-Verolme Zware Apparatenbouw b.v.
Attn: Mr. B. J. A. Sluis
Managing Director
Heijplaatstraat 4, P. O. Box 221
Rotterdam, THE NETHERLANDS


Gentlemen:

Thank you for your letter of February 19, 1980, in response to our letter dated January 14, 1980. As a result of our review, we find that additional information on the following items in the Notice of Deviation is needed:

- B. Your response fails to provide any measures to prevent recurrence relative to the use of sizing calculations performed by another company, without documented evidence of RSV-A design review.
- C. Please inform us of what actions have been taken to identify the reasons for the error in sketch requirements and the nature of subsequent corrective actions.

Please provide this additional information within twenty (20) days in order that we may complete our review in a timely manner.

Sincerely,


Uldis Potapovs, Chief
Vendor Inspection Branch

8007310176