



RSV Zware Apparatenbouw b.v.
Rotterdam Heavy Equipment

United States Nuclear Regulatory
Commission Region IV
611 Ryan Plaza Drive, Suite 1000
ARLINGTON
Texas 76012
U.S.A.
Att.: Mr. Uldis Potapovs
Chief Vendor Inspection Branch



Your ref.

Our ref. KD 80019

Rotterdam, 25th April, 1980.

Your Report Docket No. 99900039/79-02

Gentlemen,

This is to acknowledge receipt of your letter dated March 24th, 1980.
We would like to answer your letter as follows:

As regards item B we can give you the following additional information:
RSV-A will modify its Quality Assurance Manual by adding to its chapter 4,
par. 7:

- " In case the Design Report or Load Capacity Data Sheet is made and
- " verified by another N-Certificate Holder in compliance with its
- " QA System, RSV-A may limit its review to the following:
- " - checking the qualification of the N-Certificate Holder,
- " - checking that the proper Owners Certified Design Specifications,
- " Design Drawings and Code requirements are referenced.

This addition to our QA Manual to our opinion regulates satisfactorily
the use of Design Reports made by others and therefore will prevent
recurrence of deviations from Code requirements.

Relative to item C:

The error in sketch requirement proved to be the result of a human error.
As the QA engineer who checked the subject BGH-Document left RSV-A, cor-
rective actions are not possible.

To be sure that this error was not a systematic misinterpretation by the
subcontractor Boschgotthardshütte O. Breyer GmbH (BGH) of the applicable
Code requirement, extensive checking of their documents has been done in
respect to the position of test specimens.

- 2 -

8007310/79

United States Nuclear Regulatory
Commission Region IV
ARLINGTON

RSV Zware Apparatenbouw b.v.
Rotterdam Heavy Equipment

Date: 25th April, 1980.

No deviations were found, therefore RSV-A stated that the deviation does not seem to originate from any systematic deficiency, and corrective measures are not necessary. The current QA engineer who has the duty to check documents of sub-contractors did the checking mentioned earlier, so he is well informed about this subject.

We hope that our response will be satisfactory, but when you need any additional information, please contact us.

Yours faithfully,

RSV Zware Apparatenbouw b.v.



for
B.J.A. Sluis
Managing Director

W.N. van de Poll
Executive Secretary

Prepared by:

M. Lodder
Manager QA

