NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK [ ] (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 CARS S1 (2) 00-000 00 (3) 4111 1 (4) 1 (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE

CON'T
01 REPORT SOURCE L (6) 05000312 (7) 073080 (8) 071680 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During review of I&E Bulletin 79-14 work, it was discovered that a particu-
03 lar stress analysis for a nonconforming pipe support was overlooked. The
04 reanalysis of the support No. 4U-26120-6, on the discharge side of DHR pump
05 P-261A indicated stresses in excess of the allowable limits.
06
07
08

09 SYSTEM CODE CF (11) CAUSE CODE B (12) CAUSE SUBCODE A (13) COMPONENT CODE SUPORT (14) COMP. SUBCODE B (15) VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 — SEQUENTIAL REPORT NO. 031 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN F (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0000 (22) ATTACHMENT SUBMITTED Y (23) NPRD-4 FORMS N (24) PRIME COMP. SUPPLIER A (25) COMPONENT MANUFACTURER B130 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Design documentation and construction drawings were not in complete confor-
11 mance with the original seismic analysis. This was noted and flagged for
12 reanalysis but overlooked. Upon receipt of this information, the support
13 was modified to alleviate the overstress condition.
14

15 FACILITY STATUS E (28) % POWER 096 (29) OTHER STATUS (30) N/A — METHOD OF DISCOVERY D (31) DISCOVERY DESCRIPTION (32) Notification from A/E

16 ACTIVITY RELEASED Z (33) CONTENT OF RELEASE Z (34) AMOUNT OF ACTIVITY (35) N/A — LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES NUMBER 000 (37) TYPE Z (38) DESCRIPTION (39) N/A

18 PERSONNEL INJURIES NUMBER 000 (40) DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION (43) N/A

20 PUBLICITY ISSUED Y (44) DESCRIPTION (45) Local newspapers and wire service

8007310418

NRC USE ONLY

NAME OF PREPARER R. W. Colombo PHONE 916-452-3211