


~~(7)~~ (3)

SUMMARY OF  
ORIGINAL STRUCTURAL INVESTIGATIONS  
General Electric Test Reactor

presentation to  
Advisory Committee on Reactor Safeguards  
Subcommittee Meeting

June 16 & 17, 1980



**EDAC**

ENGINEERING DECISION ANALYSIS COMPANY, INC.


480 CALIFORNIA AVE., SUITE 301

PALO ALTO, CALIF. 94306

BURNITZSTRASSE 34

6 FRANKFURT 70, W. GERMANY

8008040010




SUMMARY OF STRUCTURAL INVESTIGATIONS

ORIGINAL INVESTIGATIONS

- VIBRATORY GROUND MOTION
- SURFACE RUPTURE OFFSET
- POST-OFFSET VIBRATORY MOTION
- PIPING AND EQUIPMENT

RECENT INVESTIGATIONS

- COMBINED VIBRATORY MOTIONS AND SURFACE RUPTURE OFFSET
- VIBRATORY MOTIONS ON CALAVERAS FAULT
- PIPING AND EQUIPMENT
- CONSERVATISMS IN EVALUATIONS OF REACTOR BUILDING



STRUCTURAL INVESTIGATIONSREACTOR BUILDING


- LINEAR AND NONLINEAR DYNAMIC ANALYSES
- STATIC SURFACE RUPTURE OFFSET ANALYSES

REACTOR BUILDING PIPING SYSTEMS AND COMPONENTS

- LINEAR DYNAMIC ANALYSES FOR:
  - PRIMARY PIPING
  - OTHER SAFETY-RELATED PIPING
  - REACTOR PRESSURE VESSEL
  - HEAT EXCHANGERS
  - FUEL STORAGE TANKS
  - THIRD FLOOR MISSILE IMPACT SYSTEM
  - MISCELLANEOUS COMPONENTS
- TESTING AND DYNAMIC ANALYSES FOR VALVES

FUEL FLOODING SYSTEM

- STATIC SURFACE RUPTURE OFFSET AND DYNAMIC ANALYSES, AND COMPONENT TESTING FOR:
  - STORAGE TANKS
  - SUPPLY LINES



**EDUC**







FIGURE 3-5 REACTOR BUILDING VERTICAL SECTION




**EDRAC**




Basement



First Floor




Second Floor



Third Floor

FIGURE 3-6 REACTOR BUILDING FLOOR PLANS








FIGURE 3-7 REACTOR BUILDING SAFETY-RELATED AREA



**EDAC**

BASES FOR STRUCTURAL INVESTIGATIONS

- 0.8g EFFECTIVE GROUND ACCELERATION AND RG 1.60  
RESPONSE SPECTRUM SHAPE
- 1 METER SURFACE RUPTURE OFFSET
- 1 METER OFFSET FOLLOWED BY 0.8g SEISMIC EVENT



## VIBRATORY GROUND MOTION ANALYSES

### LINEAR ELASTIC ANALYSES


- LUMPED MASS MODEL
- DYNAMIC RESPONSE
- PARAMETRIC ANALYSES
- FLOOR RESPONSE SPECTRA
- STRESSES IN CONCRETE
- CONCLUSION: Structure Is Adequate

### NONLINEAR ANALYSES

- SLIDING
- UPLIFT
- CONCRETE DUCTILITY
- STABILITY
- CONCLUSION: Linear Elastic Analyses Are Conservative

### PIPING AND EQUIPMENT

- LINEAR DYNAMIC ANALYSES
- CONSERVATIVE STATIC ANALYSES
- MODIFICATIONS WHEN REQUIRED








FIGURE 2-5 MATHEMATICAL MODEL FOR THE LINEAR ELASTIC DYNAMIC ANALYSES



**EDAC**

SURFACE RUPTURE OFFSET ANALYSES

- PHYSICAL CASES
- SELECTED CASE FOR ANALYSIS (Extreme Bound)
- CONCLUSION: Structure, Related Piping and Equipment are Adequate







FIGURE 3-2 GROUND SURFACE RUPTURE OFFSET CASES







FINDINGS OF STRUCTURAL INVESTIGATIONS

REACTOR BUILDING


- SAFETY-RELATED CONCRETE CORE STRUCTURE WILL REMAIN INTACT

REACTOR BUILDING SAFETY-RELATED PIPING SYSTEMS AND COMPONENTS

- RESTRAINTS ADDED TO PIPING SYSTEM
- RPV LATERAL SUPPORT STRENGTHENED
- RESTRAINTS ADDED TO HEAT EXCHANGERS
- FUEL STORAGE TANKS REPLACED
- MISSILE IMPACT SYSTEM INSTALLED
- OTHER COMPONENTS WILL RESIST SEISMIC FORCES

FUEL FLOODING SYSTEM


- COMPONENTS WILL RESIST SEISMIC FORCES



SUMMARY OF  
RECENT STRUCTURAL INVESTIGATIONS  
General Electric Test Reactor

presentation to  
Advisory Committee on Reactor Safeguards  
Subcommittee Meeting

June 16 and 17, 1980



**EDAC**

ENGINEERING DECISION ANALYSIS COMPANY, INC.

480 CALIFORNIA AVE., SUITE 301

PALO ALTO, CALIF. 94306


BURNITZSTRASSE 34

6 FRANKFURT 70, W GERMANY

PRESENTATION OUTLINE  
RECENT STRUCTURAL INVESTIGATIONS

- Part 1. Earthquake on Postulated Verona Fault
- Part 2. Earthquake on Calaveras Fault
- Part 3. Piping and Equipment
- Part 4. Conservatism in the Seismic Evaluations
- Part 5. Summary of Conclusions

Focus: Concrete core structure and  
related piping and equipment




**EDAC**

PRESENTATION

PART 1

ADDITIONAL INVESTIGATIONS TO DETERMINE THE EFFECTS  
OF COMBINED VIBRATORY MOTIONS  
AND SURFACE RUPTURE OFFSET DUE TO  
AN EARTHQUAKE ON THE POSTULATED VERONA FAULT




PRESENTATION OUTLINE

- PRELIMINARY COMMENTS
- GROUND MOTION CRITERIA
- HYPOTHETICAL SURFACE RUPTURE OFFSET CRITERIA
- LOAD COMBINATION CASES
- COMPONENTS OF EARTHQUAKE VIBRATORY MOTIONS
- ANALYTICAL MODEL
- STRESS ANALYSES AND CHECK AGAINST CAPACITIES
- CONCLUSIONS




PRELIMINARY COMMENTS

- Probability of occurrence of surface rupture offset (SRO) is so low that it should not be included in design bases.
- Evaluations for combined load case of SRO and vibratory motions have been performed in response to USNRC requests.
- Assumed that postulated SRO will tend to "lift" (as well as shake) the structure.
- Focus of the evaluations was on concrete core structure of Reactor Building.



## LOAD COMBINATION CASES

- Two Main Parameters of Interest
  - Vibratory Ground Motion
  - Unsupported Length
  
- Load Combinations Based on Probabilistic Considerations
  
- Load Combinations Based on Physical Argument (Soil Pressure Analyses)




GROUND MOTION CRITERIA

- Effective Horizontal Ground Acceleration: 0.40g
- Effective Vertical Ground Acceleration: 0.27g
- Response spectrum shape: Regulatory Guide 1.60

HYPOTHETICAL SURFACE RUPTURE OFFSET CRITERIA

- SRO = 1.0m



**EDAC**





FIGURE 1 HYPOTHETICAL "UNSUPPORTED LENGTH,"  $L_c$






FIGURE 2 COMBINATION OF LOADINGS BASED ON PROBABILISTIC CONSIDERATIONS (AFTER REF. 3)



**EDAC**







FIGURE 3 RESULTS OF SOIL PRESSURE ANALYSES






(a) INCIPIENT LOCAL YIELDING (ACCELERATION  $\approx 0.26g$ )




(b) INTERMEDIATE CASE ( $0.26g < \text{ACCELERATION} < 0.38g$ )




(c) UPPER LIMIT ON LOCAL YIELDING (ACCELERATION  $\approx 0.38g$ )


FIGURE 2. SOIL PRESSURE DISTRIBUTIONS (For Example Case of 13 ft Unsupported Length)




**EDAC**



RAPID LOADING AT  $Q < 20$  ksf CAUSES LOCAL YIELDING  
OF FOUNDATION SOILS



**HDAC**




RAPID LOADING AT QULT  $\approx$  20 ksf CAUSES LOCAL FAILURE OF FOUNDATION SOILS



PARAMETERS FOR  
SELECTED ANALYSIS CASE

- Ground Acceleration = 0.30g
  
- Unsupported Length = 17 ft.
  
- Conservative from Two Points of View
  - Probabilistic
  - Physical (Soil Deformations)




COMPONENTS OF EARTHQUAKEVIBRATORY MOTIONS

<u>Case</u>	<u>H1 (0.3g)</u>	<u>H2 (0.3g)</u>	<u>Vertical (0.2g)</u>
1	+ 100%	+ 40%	+ 40%
2	+ 40%	+ 100%	+ 40%
3	+ 40%	+ 40%	+ 100%

Example:


Case 1.1    HI=+0.3g    H2=+0.12g    V=+0.08g




**EDAC**

ANALYTICAL MODEL


- 3-D Finite Element
- Used Previously in Phase 2 Analyses
- Modified to Represent 17 ft. Unsupported Length
- Inertia forces are conservative





(Reprinted from Figure 3-5 of Reference 1)

**FIGURE 4 REACTOR BUILDING VERTICAL CROSS-SECTION**







FIGURE 5 REGION OF SUPPORT IN ANALYTICAL MODEL



# EDAC






FIGURE A-1 VERTICAL SECTION OF REACTOR BUILDING CORE MODEL





STRESS ANALYSES  
AND CHECK AGAINST CAPACITIES


- Capacity (initiation of cracking) =  $6\sqrt{f'_c}$
- Only 2 elements with stress ratios over 0.83  
(which corresponds to  $5\sqrt{f'_c}$ )
- No elements above first floor with stress ratios  
above  $2.9\sqrt{f'_c}$
- Highest stressed element above first floor  
(Element 735, Level 14, Figure 6)
  - Stress ratio based on capacity of  $6\sqrt{f'_c} = 0.49$   
(tensile stress).
  - Maximum stress =  $2.9\sqrt{f'_c}$ .



STRESS ANALYSES AND CHECK AGAINST CAPACITIES

-continued-

- Highest stressed element between basement and first floors (Element 749, Level 7, Figure 7)
  - Stress ratio based on capacity of  $6\sqrt{f'_c} = 0.99$   
(tensile stress)
  - Stress ratio based on capacity of  $6\sqrt{f'_c} = 0.85$   
(shear stress).
  
- Average stress ratio in elements surrounding highest stressed element  $\approx 2\sqrt{f'_c}$
  
- Estimated average shear stress between basement and first floors:
  - Stress ratio based on capacity of  $6\sqrt{f'_c} \approx 0.05$ .
  - Maximum stress  $\approx 0.3\sqrt{f'_c}$ .










FIGURE 7 PLAN - LEVEL 7



## CONCLUSIONS

- Recent analyses demonstrated that structure can withstand:
  - 17 ft/0.30g load case
  
- Previous Phase 2 analyses demonstrated that structure can withstand:
  - 20 ft/0.0g load case
  - 0 ft/0.80g load case
  
- Capacity curve demonstrates that concrete core structure can withstand all reasonable load combinations.



**EDAC**







FIGURE 11 CAPACITY CONTOUR FOR COMBINED LOADING



**EDAC**



PLAN VIEW - SHORT "UNSUPPORTED LENGTH" (~6')









FIGURE 12 LOADING VS CAPACITY





LOADING VS CAPACITY



**EDAC**

PRESENTATION

PAK 2


ADDITIONAL INVESTIGATIONS TO DETERMINE EFFECTS OF  
VIBRATORY MOTIONS DUE TO AN EARTHQUAKE  
ON THE CALAVERAS FAULT



**EDAC**

PRESENTATION OUTLINE

- GROUND MOTION CRITERIA
- COMPONENTS OF EARTHQUAKE VIBRATORY MOTIONS
- EVALUATIONS OF BUILDING




GROUND MOTION CRITERIA

- Effective horizontal ground acceleration: 0.60g
- Effective vertical ground acceleration: 0.40g
- Response spectrum shape: Regulatory Guide 1.60


COMPONENTS OF EARTHQUAKE VIBRATORY MOTIONS

<u>Case</u>	<u>H1 (0.6g)</u>	<u>H2 (0.6g)</u>	<u>Vertical (0.4g)</u>
1	<u>+100%</u>	<u>+ 40%</u>	<u>+ 40%</u>
2	<u>+ 40%</u>	<u>+100%</u>	<u>+ 40%</u>
3	<u>+ 40%</u>	<u>+ 40%</u>	<u>+100%</u>



## EVALUATIONS OF BUILDING

- PHASE 2 LINEAR ELASTIC DYNAMIC ANALYSIS WAS PERFORMED FOR 0.8g HORIZONTAL GROUND ACCELERATION.
- CONSERVATIVE INERTIA FORCES WERE OBTAINED.
- SEVERE MODEL WAS USED.
- STRESS ANALYSES SHOWED THAT THE CONCRETE STRUCTURE IS ADEQUATE.



**EDAC**







FIGURE 3-5 REACTOR BUILDING VERTICAL SECTION




**EDAC**




Basement



First Floor



Second Floor



Third Floor

FIGURE 3-6 REACTOR BUILDING FLOOR PLANS




**EDAC**

PRESENTATION


PART 3

ADDITIONAL INVESTIGATIONS TO DETERMINE EFFECTS OF  
VIRRATORY MOTIONS DUE TO AN EARTHQUAKE  
ON PIPING AND EQUIPMENT





FLOOR RESPONSE SPECTRA

- Originally obtained from lumped mass linear elastic dynamic analysis (0.8g)
- Amplitudes and widths of peaks are conservative
- Calculated H1, H2, V spectra (building global axes) were enveloped and broadened to produce H and V spectra.
- Equipment analyses were performed for h1, h2, and v directions (equipment global axes) and responses were combined by SRSS
- Spectra for 0.6g case are enveloped by 0.8g design case (see figure)
  - Primary cooling system run 1,  $f_1 = 7.4\text{Hz}$
  - Primary cooling system run 2,  $f_1 = 11.4\text{ Hz}$
  - HE101,  $f_1 = 19.1\text{Hz}$
  - Control rod drive assembly,  $f_1 \geq 33\text{Hz}$ ,  $f_1' > 13\text{Hz}$
  - Incore shuttle drive assembly,  $f_1 > 33\text{Hz}$



**EDAC**




ENVELOPE FLOOR RESPONSE SPECTRA FOR HORIZONTAL MOTION  
AT ELEVATION 611.0 FT 7.0 IN.

**EDAC**

PRESENTATION


PART 4

CONSERVATISMS IN THE SEISMIC EVALUATIONS  
OF THE GETR REACTOR BUILDING



CONSERVATISMS IN THE SEISMIC EVALUATIONS  
OF THE GETR REACTOR BUILDING

- Many conservatisms exist in the seismic evaluations of the GETR Reactor Building.
  
- Conservatisms are inherent in
  - Selection of seismic criteria which quantify postulated seismic events,
  
  - Analytical procedures used to determine the response of the structure to the postulated events,
  
  - The acceptance criteria for the structure.
  
- Conservatisms tend to over-estimate response and under-estimate capacities.



CONSERVATISMS IN THE SEISMIC EVALUATIONS  
OF THE GETR REACTOR BUILDING

(Continued)

- o Actual overall safety margin is substantial.
- o Objective is to point out the conservatisms which exist, and illustrate the likely influence of these conservatisms on the total safety margin.
- o Permits, as a minimum, the qualitative conclusion that the total safety margin is substantially above the values determined by the conservative seismic evaluations of the GETR Reactor Building.




TABLE 1SUMMARY LIST OF AREAS OF CONSERVATISMCHARACTERIZATION OF EARTHQUAKES

1. Selection of a Low Probability Extreme Event
2. Use of Wide-Band Ground Response Spectra
3. Conservative Amplification Factors in Response Spectra
4. Duration of Time History of Input Motions
5. Decrease of Ground Motions With Depth
6. Propagation of Seismic Waves Beneath the Base of a Building of Finite Width ("Tau Effect")

POSTULATED VERONA FAULT


7. Postulated Surface Rupture Offset
8. "Unsupported Length" in Surface Rupture Offset Case

ANALYTICAL MODELS

9. Modeling Assumptions -- Response Models
10. Modeling Assumptions -- Stress Analysis Model
11. Embedment Effects
12. Additional Nonlinear Effects


STRENGTH AND CAPACITY

13. Static Versus Dynamic Strength
14. Concrete Strength
15. Energy Dissipation Capacity



CONCLUSIONS

- There are numerous conservatisms in the procedures used to evaluate the adequacy of the GETR Reactor Building.
- Conservatisms are cumulative.
- Illustration of influence of conservatisms on total safety margin
  - Assume Loads (L) = Capacities (C) = 1.0  
as calculated by conventional procedures.
  - Assume actual Loads,  $L' = 0.7L = 0.7$
  - Assume actual Capacities,  $C' = 1.3C = 1.3$
  - Actual safety margin =  $(1.3)/(0.7) = 1.9$




**EDAC**

CONCLUSIONS

-continued-

- If all individual margins were quantified, the result would be a total margin of safety significantly above (and likely on the order of at least two times) that conservatively determined by the seismic evaluations of the GETR Reactor Building.





**EDAC**

PRESENTATION


PART 5

SUMMARY OF CONCLUSIONS






LOADING VS CAPACITY



## GETR LANDSLIDE INVESTIGATIONS

- |  |                        |                |
|--|------------------------|----------------|
| o Geologic investigations, assessment of surficial and large-scale landsliding | Phase I report         | February, 1978 |
| o Relative stability analysis, simplified slip-circle analyses                 | Report                 | July, 1978     |
| o Review of relative stability analysis in light of Phase II investigations    | Phase II report        | February, 1979 |
| o CDMG simplified slip-circle analyses   | Special Publication 56 | August, 1979   |
| o Parametric stability analyses  | Meeting with NRC       | January, 1980  |
| o Proposed program of field and laboratory investigations and analyses         | Submittal              | March, 1980    |
| o Slope monitoring program   |                        | May, 1980      |



PROPOSED FIELD AND LABORATORY  
INVESTIGATIONS AND ANALYSES

Field Investigation


- borings
- e-logging
- piezometer installation
- test pits (contingency)



Laboratory Investigations

- index properties
- static triaxial testing
- direct shear testing (possible option)
- cyclic triaxial and post-cyclic static triaxial testing (possible option)

Analyses

- static analysis using STABL2
- pseudo-static analysis using STABL2
- simplified deformation analysis after Makdisi and Seed, 1978






GETR PLOT PLAN  
RANGE OF VIEW OF EXCAVATION PHOTOGRAPHS

## SOIL STRATIGRAPHY AND AGE DATING

- Age of buried paleosols
- Age of sediments under GETR
- Age of modern solum




---

---

---

### SUMMARY OF SOIL-STRATIGRAPHY

- Upper buried paleosol developed during isotope stage 5-70,000 to 125,000 years B.P.
- Underlying sediments are of stage 6 age; deposited about 125,000 to 200,000 years B.P.
- Sediments in the GETR foundation are at least 125,000, and more likely 350,000 years old.
- The modern solum is developing on sediments laid down in latest Pleistocene time.
- The albic horizon (Ae) may occur at any position within the profile.
- Radiocarbon ages must be corrected for (1) mean residence time, and (2) modern organic matter contamination.
- Last displacement on the B-1/B-3 and B-2 shears took place before about 8,000 years B.P.






Figure A-9: Soil-stratigraphy, west wall, Trench B-2; ESA stations 1+00-1+20. Representative soil profile measured at station 1+00 (Table 3). Albic horizon (Ae) extends into lower B<sub>1</sub> of modern solum below shear (station 1+14). Radiocarbon sample localities indicated by laboratory number (e.g., GX-6011; see Table 1).




Figure A-9: Soil-stratigraphy, west wall, Trench B-2; ESA stations 1+00-1+20. Representative soil profile measured at station 1+00 (Table 3). Albic horizon (Ae) extends into lower B<sub>1</sub> of modern solum below shear (station 1+14). Radiocarbon sample localities indicated by laboratory number (e.g., GX-6011; see Table 1).




Figure A-8: Soil-stratigraphy, west wall, Trench B-1; ESA stations 0+60-0+80. Representative soil profile measured at station 0+60 (Table 2). Dominant shear extends into III B<sub>t</sub> horizon of modern solum. Radiocarbon sample localities indicated by laboratory number (e.g., GX-6008; see Table 1).





Figure A-8: Soil-stratigraphy, west wall, Trench B-1; ESA stations 0+60-0+80. Representative soil profile measured at station 0+60 (Table 2). Dominant shear extends into III B<sub>t</sub> horizon of modern solum. Radiocarbon sample localities indicated by laboratory number (e.g., GX-6008; see Table 1).

SUMMARY

- o THE GEOLOGIC INVESTIGATION WAS THOROUGH AND RESPONSIVE TO SUGGESTIONS FROM THE NRC STAFF AND USGS
- o THE SEISMIC DESIGN BASIS SPECIFIED BY NRC STAFF IS VERY CONSERVATIVE
- o ANALYSES SHOW THE GETR CONCRETE STRUCTURE AND SAFETY RELATED EQUIPMENT WILL PERFORM THEIR REQUIRED FUNCTIONS DURING AND AFTER THE POSTULATED EVENT AND THE FUEL WILL REMAIN COVERED WITH WATER
- o THE PROPOSED LANDSLIDE STABILITY ANALYSIS WILL BE COMPLETED AND IT IS CONTEMPLATED THAT IT WILL RECEIVE APPROVAL BY THE NRC STAFF
- o REQUEST A REVIEW BEFORE THE FULL ACRS COMMITTEE AT THE EARLIEST POSSIBLE OPPORTUNITY



RWD:6/13/80