

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK [] [] [] [] [] [] [] [] (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(01) | C | A | I | R | I | S | | 1 | | 0 | 0 | - | 0 | 1 | 0 | 1 | 0 | 1 | - | 0 | 1 | 0 | 3 | | 4 | 1 | 1 | 1 | 1 | 1 | | 5 |
LICENSEE CODE 14 15 LICENSE NUMBER 19 20 21 22 23 24 25 26 27 28 29

CONT

(01) | R | | L | 5 | 0 | 1 | 5 | 1 | 0 | 1 | 0 | 1 | 3 | 1 | 1 | 2 | 1 | 2 | 0 | 1 | 7 | 1 | 1 | 2 | 8 | 1 | 0 | 7 | 1 | 1 | 8 | 8 | 1 | 3 |
REPORT SOURCE 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

(07) | On 7/12/80, while performing a routine surveillance test on AFW pump P-318,
 (03) | the pump failed to start (via the turbine as the prime mover) from the
 (04) | control room. After two unsuccessful attempts, an operator was sent to
 (05) | investigate. No apparent problems were found. Subsequent start attempts
 (06) | proved successful.
 (07) |
 (08) |

SYSTEM CODE S E (11)		CAUSE CODE X (12)		CAUSE SUBCODE Z (13)		COMPONENT CODE T U R B I N E (14)			COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)				
LER NO. REPORT NUMBER 8 0 (17)		EVENT YEAR 8 0 (18)		SEQUENTIAL REPORT NO. 0 1 3 2 (19)		OCCURRENCE CODE 0 1 3 (20)		REPORT TYPE L (21)		REVISION NO. 0 (22)					
ACTION TAKEN X (23)		EFFECT ON PLANT Z (24)		SHUTDOWN METHOD Z (25)		HOURS 0 0 1 0 0 (26)		ATTACHMENT SUBMITTED Y (27)		NRC-4 FORM 608 N (28)		PRIME COMPONENT SUPPLIER A (29)		COMPONENT MANUFACTURER I I I 4 7 (30)	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (37)

(10) | Since the cause of the failure could not be determined, a series of daily
 (11) | "confidence starts" was run on the unit. After successfully starting for
 (12) | five consecutive days, unit testing was returned to the normal surveillance
 (13) | test frequency.
 (14) |

FACILITY STATUS E (31)		% POWER 0 9 1 6 (32)		OTHER STATUS N/A (33)		METHOD OF DISCOVERY B (34)		DISCOVERY DESCRIPTION Routine Surveillance (35)	
ACTIVITY RELEASED OR RELEASE Z (36)		AMOUNT OF ACTIVITY N/A (37)		LOCATION OF RELEASE N/A (38)					
PERSONNEL EXPOSURES NUMBER 0 1 0 0 (39)		TYPE Z (40)		DESCRIPTION N/A (41)					
PERSONNEL INJURIES NUMBER 0 0 0 0 (42)		DESCRIPTION N/A (43)							
LOSS OF OR DAMAGE TO FACILITY TYPE Z (44)		DESCRIPTION N/A (45)							
PUBLICATION ISSUED DESCRIPTION Y (46)		Local newspapers and wire service. Y (47)		NRC USE ONLY					

NAME OF PREPARED: **2.008050 2.88** R. W. Colombo

PHONE: **916-452-3211**