MORTHEAST UTILITIES



P.O. BOX 270 HARTFORD, CONNECTICUT 06101 (203) 686-6911

July 27, 1980

Docket No. 50-245 A01137

Mr. Boyce H. Grier, Director Region 1 Office of Inspection and Enforcement U. S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406

Reference: (1) B. H. Grier letter to W. G. Counsil dated July 22, 1980.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 1 I&E Bulletin No. 80-17, Supplement No. 2

This letter responds to I&E Bulletin No. 80-17, Supplement No. 2, which was transmitted to us in Reference (1). Millstone Unit No. 1 has a Scram Discharge Volume (SDV) vent system on both the north and south sides that is dependent only upon the respective vent valves for proper venting, the vent path is continuously open to building atmosphere on the side of the vent valve away from the SDV.

The south side has had this proper configuration. However, a modification to the north side was necessary since the SDV vent system on that side discharged to the Scram Discharge Instrument Volume drain line, between the drain valve and the Reactor Building Equipment Drain Tank. The modification to the north side was performed on July 22, 1980, such that Millstone Unit No. 1 is now in compliance with the Bulletin, Supplement No. 2 requirement.

As requested by the Bulletin, we estimate that an additional three (3) man-days were expended on this Supplement.

Should you have any questions, please contact us.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Counsil

Senior Vice President

Add: J Shea - 1

A001 510

8008050330