

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M | T | B | R | P | I | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 1 | 4 | _____ | 5
7 8 9 14 15 25 26 30 37 38 58 59 64 65 70 71 72 73 74 75 76 77 78 79 80

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | - | 0 | 1 | 5 | 5 | 7 | 10 | 17 | 0 | 3 | 18 | 10 | 8 | 0 | 3 | 0 | 1 | 18 | 10 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | Following intermittent automatic test circuit alarms, the sensor channel
03 | D of the Reactor Depressurizing System was removed from service to correct
04 | the problem. All four blowdown loops remained operable under this condition
05 | with 2/3 logic instead of 2/4. No hazard occurred and the equipment was
06 | restored to operable status in less than four hours. Similar to RO-80-16.
07 | Reportability is based on Tech Specs 6.9.2.b(2).
08 | _____

09 | SYSTEM CODE | S | H | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | 3 | 13 | COMPONENT CODE | Z | Z | Z | Z | Z | Z | 14 | COMP. SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16 |
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 | LER/RO REPORT NUMBER | 1 | 8 | 0 | EVENT YEAR | 1 | 8 | 0 | SEQUENTIAL REPORT NO. | 0 | 1 | 7 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | REVISION NO. | 0 |
21 22 23 24 25 26 27 28 29 30 31 32
18 | ACTION TAKEN | X | 18 | 19 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 0 | ATTACHMENT SUBMITTED | Y | 23 | NPD-4 FORM SUB. | Y | 24 | PRIME COMP. SUPPLIER | Z | 25 | COMPONENT MANUFACTURER | 9 | 9 | 9 | 9 | 26
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Setpoint drift in the conservative direction on reactor level transmitter
11 | LT-3183 caused the alarm. The unit was readjusted by venting and rezeroing
12 | the transmitter. Removal of the equipment from service is allowed per
13 | Tech Spec 11.3.1.5-3. Investigation of the cause of drift is planned during
14 | a future outage.

15 | FACILITY STATUS | E | 28 | % POWER | 0 | 8 | 7 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operator Observation | 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
16 | ACTIVITY RELEASED OF RELEASE | Z | 33 | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
20 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

8008050447