

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-346THE TOLEDO EDISON COMPANYANDTHE CLEVELAND ELECTRIC ILLUMINATING COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 28 to Facility Operating License No. NPF-3, issued to The Toledo Edison Company and The Cleveland Electric Illuminating Company (the licensees), which revised the license and Technical Specifications for operation of the Davis-Besse Nuclear Power Station, Unit No. 1 (the facility) located in Ottawa County, Ohio. The amendment is effective as of its date of issuance.

This amendment revises the Technical Specification setpoint for the automatic closure of the decay heat removal system isolation valves, and implements a pressurizer heater interlock which deenergizes the heaters if reactor coolant system pressurization is attempted and both decay heat removal system isolation valves are not closed. This action satisfies the requirements of license conditions 2.C.(3)(d) and 2.C.(3)(j). In addition, the amendment adds a new condition to the license which requires, prior to operation beyond five effective full power years, the Toledo Edison Company to provide a reanalysis and proposed modifications, as necessary, to ensure continued means of protection against low temperature reactor coolant system overpressure events. Therefore, license condition 2.C.(3)(d) is replaced with the above new requirement and condition 2.C.(3)(j) is removed from the license.


The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated March 20, 1978, (2) Amendment No. 28 to License No. NPF-3, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and at the Ida Rupp Public Library, 310 Madison Street, Port Clinton, Ohio. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 25th day of July 1980.

FOR THE NUCLEAR REGULATORY COMMISSION


Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Licensing