

July 24, 1980

Mr. James G. Keppler, Regional Director Office of Inspection and Enforcement Region III U. S. NUCLEAR REGULATORY COMMISSION 799 Roosevelt Road Glen Ellyn, IL 60137

Dear Mr. Keppler:

REPLY TO IE BULLETIN 80-16
POINT BEACH NUCLEAR PLANT

Your letter of June 27, 1980, forwarded IE Bulletin 80-16, "Potential Misapplication of Rosemount Inc. Hodels 1151 and 1152 Pressure Transmitters with either "A" or "D" Output Codes".

A review of transmitter applications at the Point Beach Nuclear Plant indicated that there are no Rosemount Inc. Model 1151 or 1152 pressure transmitters with output codes "A" or "D" installed in any safety related application. Also there are no present plans to install these units in any safety related application.

Very truly yours,

C. W. Fay, Director Nuclear Power Department

Copy to: U. S. NUCLEAR REGULATORY COMMISSION

Office of Inspection and Enforcement Division of Reactor Operations Inspection

Washington, D. C. 20555

NRC Resident Inspector Point Beach Nuclear Plant