

REGULATORY DOCKET FILE COPY AUG 1 1980

Central Files 50-348

MEMORANDUM FOR: V. S. Noonan, Assistant Director
for Materials and Qualifications Engineering
Division of Engineering

FROM: S. S. Pawlicki, Chief
Materials Engineering Branch
Division of Engineering

SUBJECT: CORRECTION TO JULY 17, 1980 MEMORANDUM REGARDING MAGNITUDE
OF RECENT STEAM GENERATOR LEAK AT FARLEY UNIT 1

Our July 17, 1980 memorandum, S. S. Pawlicki to V. S. Noonan, contains an error regarding the magnitude of June 18, 1980 steam generator leak at Farley Unit 1. The actual leakage rate was approximately 117 gpd (gallons per day), rather than 117 gpm (gallons per minute). This was a relatively small leak compared to that which would result from a major tube rupture, and was less than the Technical Specification leak rate limit of 500 gpd.

S. S. Pawlicki, Chief
Materials Engineering Branch
Division of Engineering

Contact: E. L. Murphy
X37041

Distribution:
Central File
NRR Reading File
MTEB Reading File
Filing Index SP-1

- cc: R. H. Vollmer
- D. G. Eisenhut
- R. J. Mattson
- H. M. Fontecilla
- R. L. Tedesco
- J. P. Knight
- T. Movak
- G. Lafnas
- E. Brown
- V. Benaraya
- R. J. Bosnak
- C. Berlinger
- W. S. Hazelton
- S. A. Varga
- D. Crutchfield
- B. D. Liaw
- R. M. Gamble
- P. Mathews
- J. Strosnider
- E. L. Murphy

8008080 203

5

OFFICE	DE: MTEB	DE: MTEB	DE: MTEB
SURNAME	EL Murphy: gj	BD Liaw	SS Pawlicki
DATE	7/30/80	7/29/80	7/31/80