

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C | A | R | I | S | S | 1 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 4 | 1 | 1 | 1 | 1 | 1 | 1 | 4 | 1 | 1 | 1 | 5

0 1 | L | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 1 | 2 | 0 | 6 | 1 | 2 | 8 | 0 | 0 | 7 | 3 | 0 | 8 | 0 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 7 | A review of the June 1980 effluent monitoring charts indicated that the
0 5 | plant liquid effluent pH exceeded the 8.5 limit established by Technical
0 4 | Specifications Appendix B, Section 2.4. On June 2, 1980, the pH spiked to
0 5 | 8.7 for approximately 15 minutes.
0 6 |
0 7 |
0 8 |

0 5 | SYSTEM CODE [W | G |] CAUSE CODE [C |] CAUSE SUBCODE [Z |] COMPONENT CODE [Z | Z | Z | Z | Z | Z |] COMP SUBCODE [Z |] VALVE SUBCODE [Z |]

17 | LER NO REPORT NUMBER [8 | 0 |] EVENT YEAR [8 | 0 |] SEQUENTIAL REPORT NO. [0 | 1 | 3 | 4 |] OCCURRENCE CODE [0 | 1 | 4 |] REPORT TYPE [1 |] REVISION NO. [0 |]
ACTION TAKEN [X |] FUTURE ACTION [Z |] EFFECT ON PLANT [Z |] SHUTDOWN METHOD [Z |] HOURS [0 | 0 | 0 | 0 |] ATTACHMENT SUBMITTED [Y |] APPROX FORMULS [N |] PRIME COMP SUPPLIER [Z |] COMPONENT MANUFACTURER [Z | Z | Z | Z |]

1 0 | It was concluded that the 6/2/80 pH problem was a continuation of the
1 1 | problems which occurred in May 1980. This was reported via LER 80-29.
1 2 | The corrective action initiated as a result of the May 1980 occurrences
1 3 | are deemed sufficient to minimize recurrence.
1 4 |

1 5 | FACILITY STATUS [E |] % POWER [0 | 9 | 6 |] OTHER STATUS [N/A] METHOD OF DISCOVERY [B |] DISCOVERY DESCRIPTION [Review of recorder charts.]

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE [Z |] AMOUNT OF ACTIVITY [N/A] LOCATION OF RELEASE [N/A]

1 7 | PERSONNEL EXPOSURES NUMBER [0 | 0 | 0 | 0 |] TYPE [Z |] DESCRIPTION [N/A]

1 8 | PERSONNEL INJURIES NUMBER [0 | 0 | 0 | 0 |] DESCRIPTION [N/A]

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE [Z |] DESCRIPTION [N/A]

2 0 | PUBLICITY ISSUED DESCRIPTION [Y |] Local newspapers and wire services.

8008060390

NAME OF PREPARER R. W. Colombo

PHONE 916-452-3211