

TIC



KANSAS GAS AND ELECTRIC COMPANY

GLENN L. KOESTER
VICE PRESIDENT-OPERATIONS

July 3, 1980

Mr. W.C. Seidle, Chief
Reactor Construction and
Engineering Support Branch
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive - Suite 1000
Arlington, Texas 76012

KMLNRC-011
Re: NRC Docket No. 50-482
Subj: Interim Report Potential 50.55(e)
Industrial Mechanics, Inc 2-3/4" Nuts and Bolts

Dear Mr. Seidle:

On June 6, 1980, Messrs. Earl Creel and M.E. Clark reported to Messrs. W. Crossman and W. Hubacek of NRC Region IV that some 2-3/4" anchor bolts and nuts supplied to the Wolf Creek Site by Industrial Mechanics, Inc. have minimum and maximum diameters which do not conform to the tolerance limitation specified in ANSI B1.1-1960.

In order to determine the extent of the problem and its safety significance, the lead Architect/Engineer has requested that additional information be provided by the site Contractor. The investigation to determine the extent of the discrepancy will include the 2-3/4" size nuts and bolts initially identified as nonconforming, plus other sizes supplied by Industrial Mechanics. We expect that approximately three to four months will be needed to obtain and analyze the information; thus, a supplemental response regarding this problem will be submitted by October 31, 1980.

Yours very truly,

Glenn L. Koester

GLK:bl

8008080426

5