CONTROL BLOCK: | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | C | T | M | N | S | 2 | (2) | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | (3) | 4 | 1 | 1 | 1 | 1 | (4) | | | (5)

LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

REPORT SOURCE | L | (6) | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 6 | (7) | 0 | 7 | 0 | 3 | 8 | 0 | (8) | 0 | 8 | 0 | 4 | 8 | 0 | (9)

DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During routine surveillance the 'A' HPSI pump siezed. The 'A' HPSI pump and the 'A' service water header were declared inoperable and the plant operated in accordance with Sections 3.5.2 and 3.7.4.1 of the Technical Specifications. The 'A' service water header was declared inoperable to allow the 'A' service water strainer to be removed and installed in place of the inoperable 'C' service water strainer. This allowed 4.16KV bus 24E to be shifted to Facility I restoring independent service water and HPSI headers with the 'B' HPSI and service water pumps on Facility I. Similar events - none.

SYSTEM CODE: S F (11) — CAUSE CODE: D (12) — CAUSE SUBCODE: Z (13) — COMPONENT CODE: P U M P X X (14) — COMP. SUBCODE: B (15) — VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER — EVENT YEAR: 8 0 — SEQUENTIAL REPORT NO.: 0 2 4 — OCCURRENCE CODE: 0 3 — REPORT TYPE: L — REVISION NO.: 0

ACTION TAKEN: D (18) — FUTURE ACTION: G (19) — EFFECT ON PLANT: Z (20) — SHUTDOWN METHOD: Z (21) — HOURS (22): 0 0 0 0 — ATTACHMENT SUBMITTED: N (23) — NPRD-4 FORM SUB.: Y (24) — PRIME COMP. SUPPLIER: A (25) — COMPONENT MANUFACTURER: I b 7 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The 'A' HPSI pump siezed because the normally 'locked open' pump minimum flow valve was found unlocked and shut. A valve lineup of the HPSI System was not perfomned following maintenance during the previous outage and the valve is not listed on the surveillance valve lineup. Procedures are being revised to address valve lineups following maintenance and to check valve lineups for completeness.

FACILITY STATUS: E (28) — % POWER: 1 0 0 (29) — OTHER STATUS (30): NA — METHOD OF DISCOVERY: B (31) — DISCOVERY DESCRIPTION (32): Surveillance Test

ACTIVITY RELEASED: Z (33) — CONTENT OF RELEASE: Z (34) — AMOUNT OF ACTIVITY (35): NA — LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES — NUMBER: 0 0 0 (37) — TYPE: Z (38) — DESCRIPTION (39): NA

PERSONNEL INJURIES — NUMBER: 0 0 0 (40) — DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY — TYPE: N (42) — DESCRIPTION (43): NA

PUBLICITY — ISSUED: N (44) — DESCRIPTION (45): NA

8108110 1336

NRC USE ONLY

R. A. Stratman 203-447-1791