8	LICENSEE EVENT REPORT
	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	M A P P S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5 CAT 56
CON'T	REPORT L 6 0 5 0 - 0 2 9 3 7 0 6 2 1 8 0 8 0 5 8 0 9 SVENT DATE 74 75 REPORT DATE 80
0 2	On June 21, 1980 at approximately 0730 hours during a routine check by control
0 3	room operators it was observed that the off gas radiation monitors RM 1705-3A & B
0 4	on panel C910 were reading low (5 mr versus 100 mr). An immediate investigation
0 5	revealed that low sample flow existed to the Off Gas Sample Rack. The operator
0 6	adjusted the sample flow to the posted level and the readings returned to normal.
07	
08	9 30
0 9 7 8	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC
	LER/RO EVENT YEAR REPORT NO. 17 REPORT NUMBER 21 22 23 24 26 27 28 29 30 31 31 31 32 34 35 36 37 40 41 23 42 43 43 43 44 47 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10	Problems encountered with offgas condenser apparently adversely affected flow to
111	the Off Gas Sample Rack. Radiation levels were not reduced sufficiently to
1 2	generate a low level alarm. During this period post treatment and stack gas
1 3	radiation levels were normal.
7 8	9 90
1 5	STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 E 28 1 0 0 29 NA B 31 Routine Inspection 9 10 12 13 44 45 46
	CTIVITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY 35 Z 33 Z 34 NA NA PERSONNEL EXPOSURES AMOUNT OF ACTIVITY 35 NA NA NA NA NA NA NA
1 7 7 8	NUMBER TYPE DESCRIPTION (39) NA PERSONNEL INJURIES NA 80
1 8	NUMBER DESCRIPTION (41) NA NA
1 9	LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION NA
20	SSUED DESCRIPTION 45 8008110,310 NRC USE ONLY 80 NRC USE ONLY 68 69 80 80 80 80 80 80 80 80 80 8