



Metropolitan Edison Company
Post Office Box 480
Middletown, Pennsylvania 17057
717 944-4041

Writer's Direct Dial Number

August 5, 1980
TLL 383

Office of Inspection and Enforcement
Attn: Mr. Boyce H. Grier, Director
Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit II (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Licensee Event Report 80-028/03L-0

Attached please find Licensee Event Report 80-028/03L-0, concerning the high crankcase pressure trip of Emergency Diesel Generator DF-X-1B, on July 7, 1980.

This event constitutes a violation of Section 3.8.1.1.b and is considered reportable under Section 6.9.1.9.b of the Interim Recovery Technical Specifications.

Sincerely,

/s/ G. K. Hovey

G. K. Hovey
Director, TMI-II

GKH:SDC:dad

Attachments (2)

cc: J. T. G...
Snyder

A002
s
//

8008120504