

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

August 8, 1980

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Schwencer:


In the Matter of the Application of) Docket No. 50-327
Tennessee Valley Authority)

A TVA-NRC meeting was held on July 29, 1980, to discuss the design of the TVA interim distributed ignition system for control of hydrogen in the Sequoyah Nuclear Plant containment. Enclosed are TVA's complete responses to 10 of the 11 action items requested of TVA during the July 29, 1980, meeting. Enclosure 1 is a list of the action items with a summary of the TVA response. Action item 7b, an analysis of heat fluence delivered to equipment and resultant equipment temperature environment will be submitted on or before August 12, 1980.

TVA was also requested to provide operational testing data on the igniters. This testing data will be submitted as soon as available.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosure

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES


8008120518

B021
S
1/1

ENCLOSURE 1


TVA ACTION ITEMS FROM JULY 29, 1980, MEETING
ON INTERIM DISTRIBUTED IGNITION SYSTEM

1. Commitment to Use General Motors Glow Plug - TVA commits to the use of the General Motors Glow Plug as the igniter in the interim distributed ignition system for the Sequoyah Nuclear Plant.
2. Location Drawings - Attached are the location drawings, figures 1 to 6, for each elevation.
3. Mounting Details - Attached is a drawing showing mounting details, figure 14.
4. Location of Igniter Switch Panel - Figure 5 shows the location of the lighting switch panel LS-4 which controls the igniters.
- 5a. Location of Hydrogen Monitors - See figure 7.
- 5b. Location of Hydrogen Monitor Intakes - See figures 1-6.
6. Hydrogen Monitor Description - See Enclosure 2.
- 7a. List of Components Required after Hydrogen Burns - See Enclosure 3.
- 7b. Analysis of Expected Equipment Environment - An analysis of expected temperature and assumed heat fluence will be provided on or before August 11, 1980.
8. Containment Cooling System Capability - See Enclosure 4.
9. Radiative Heat Calculations - See Enclosure 5.
10. Analysis of a Burn without Ice Condenser Benefits - See Enclosure 6.
11. Presentation by R. Bruce, OPS, on July 29, 1980 - See Enclosure 7.



SECTION D12-D14

CONTAINMENT LIGHTING
FIGURE I.



CONTAINMENT
LIGHTING FIXTURES
EL.689.0'
FIGURE 2

KEY TO FIGURES 2 THROUGH 6

Denotes normal lighting fixtures (LC) - ○

Denotes standby lighting fixtures (LS) - ⊙

Fixture Description

Format: "X-Y" , where

X is one of the following;

L- fixture containing a lightbulb

G- fixture containing glowplug type igniter

Y is one of the following;

A- phase A electricity

B- phase B electricity

C- phase C electricity

Denotes H₂ sampling location:

① El. 674.78 Az. 280°


② El. 716.0 Az. 310°

③ El. 716.6 Az. 230°


④ El. 730.0 Az. 310°

⑤ El. 756.0 Az. 90°


⑥ El. 756.0 Az. 315°




CONTAINMENT
LIGHTING FIXTURES
EL 700.0
FIGURE 3



CONTAINMENT
LIGHTING FIXTURES
EL 731.0'
FIGURE 4



CONTAINMENT
 LIGHTING FIXTURE
 EL 792.0'
 FIGURE 5



CONTAINMENT
LIGHTING FIXTURES
EL. 818.0'
FIGURE 6






FIGURE 8





卷之三

FIGURE 9






FIGURE 10



4' 0" x 6' 0"	4' 0" x 6' 0"
4' 0" x 6' 0"	4' 0" x 6' 0"
4' 0" x 6' 0"	4' 0" x 6' 0"
4' 0" x 6' 0"	4' 0" x 6' 0"
4' 0" x 6' 0"	4' 0" x 6' 0"

FIGURE II






FIGURE 12

SILOAM NUCLEAR PLANT	
TENTATIVE SITE PLAN	
Scale 1/2500	100' 0"
100'	0"
200'	0"
300'	0"
400'	0"
500'	0"
600'	0"
700'	0"
800'	0"
900'	0"
1000'	0"





FIGURE 13




STAND-BY
LIGHTING PANEL
LS-4

30 AMP
BREAKER

120 VAC

FUSE BOX

30 AMP
FUSE



TYPICAL OF ONE CIRCUIT

(NUMBER OF GLOW PLUGS PER CIRCUIT VARIES FROM
ONE TO EIGHT)

REV NO.	ECR NO.	DATE	DSGN ORWNC HD SUPV ENGR	SP SUBM PRCN APPD
DSGN			INSP	
ORWNC				
CHLD			ENGINEER	
SUPV				

ELECTRICAL SCHEMATIC
FIGURE 15

TENNESSEE VALLEY AUTHORITY

DIVISION OF ENGINEERING DESIGN

SUBMITTED

RECOMMENDED

APPROVED

KNOXVILLE

RECORD DRAWING AS CONSTRUCTED

ENCLOSURE 2

Description of Hydrogen Analyzer System at Sequoyah Nuclear Plant

The hydrogen analyzer system installed in each unit of Sequoyah Nuclear Plant consists of two independently-trained, redundant, hydrogen analyzers and is designed to sample the containment atmosphere for the presence of hydrogen and relay the measured atmospheric hydrogen concentrations to the main control room. System design calls for continuous operation during an accident under containment conditions of 2 to 50 psig and 40 to 290° F. The sampling system is seismic category I, and conforms to ASME Section III, Class 2, and Section IX requirements: ANSI B16.5, B16.11, N45.2, and B46.1 requirements; and the applicable requirements of the ASTM, IEEE, etc.

Each analyzer has a single 3/8" input sampling line which branches into two 3/8" lines immediately before entering primary containment - one line penetrating into the upper compartment and the other into the lower compartment. See Figure 7. Each branch line is equipped with a normally closed, air operated, remote manually controlled, isolation valve. Upon actuation of the system the containment atmosphere is drawn through a series of sample conditioners including a trap, moisture separator, and filter before entering the analyzer. The sample is returned to primary containment via a 3/8" line. The return line is also equipped with a remote manually controlled isolation valve, normally closed. The analyzer is designed to operate under the conditions of pressure, temperature, humidity and radiation associated with a LOCA. Each analyzer is calibrated to measure

hydrogen concentrations between 0 and 10 percent with an accuracy of one percent full scale. A schematic drawing of an analyzer is given in Figures 8 and 9. Sample suction and expulsion locations are shown in Figures 10, 11, 12, and 13.

Analysis is accomplished by utilizing the technology for thermal conductivity measurements of gases. The analysis technique utilizes a hot filament fixed in the center of a temperature controlled metal cavity. The filament temperature is determined by the amount of heat conducted to the cavity wall by the gas present. Thermal conductivity varies with gas species, thus causing the filament temperature to change as the gas in the cavity changes. Since filament resistance changes with temperature; by using two filaments in separate cavities and connecting them in an electrical bridge, the difference in thermal conductivity of gases in the separate cavities may be determined electrically. Electrical zero is set by first introducing the same gas to both cavities and then, adjusting the bridge so that the bridge will be balanced, resulting in zero output. Then, as different gases are introduced to the two individual cavities, the bridge will become unbalanced, and the electrical output will increase with increasing differences in thermal conductivity of the gases used.

The measurement of hydrogen in the presence of nitrogen, oxygen, and water vapor is possible because the thermal conductivity of hydrogen is approximately seven times greater than nitrogen, oxygen, or water vapor, which have nearly identical thermal conductivities at the filament operation temperature of approximately 500° F. Hydrogen measurement is accomplished by using a thermal conductivity

measurement cell and a catalytic reactor. The sample first flows through the reference section of the cell, then passes through the catalytic converter where free oxygen is catalytically recombined with hydrogen to form water vapor, and finally flows through the sample section of the measuring cell. The hydrogen content is indicated by the difference in thermal conductivity between the sample and reference sides of the cell.

The hydrogen analyzers will be in the "stand-by" mode at all times during normal operation. Upon occurrence of an accident, the reactor operator opens the isolation valves and switches the analyzer to the "ON" mode to obtain hydrogen concentration information.

ENCLOSURE 3

Components Required After Hydrogen Burns

<u>Component</u>	<u>Location Inside Containment</u>	<u>Function</u>
Limit switches	Upper and lower	
FCV67-87, -95, -103, -111	Lower compartment	Lower containment cooler discharge
FCV67-295, -296, -297, -298	Upper compartment	Upper containment vent cooler
FCV70-87	Lower compartment	RCP thermal barrier
FCV7-89	Lower compartment	RCP oil cooler
LT3-148, -156, -164, -171, -172, -173, -174, -175	Lower compartment	Steam generator level transmitters (narrow range)
30-1AA, 30-1BB	Lower compartment	Containment air return fans
Penetrations		Medium voltage power, low voltage power, and control and instrumentation
Splices		
Junction boxes	Lower compartment	RTD connections to measure TCS temperature
FCV62-61	Lower compartment	Valve motor operator
FCV63-67, -80, -98, -118, -172	Lower compartment	Valve motor operator
TE68-2A&B, -14, -25, -37, -44, -56, -67, -79 (-410, 411, 420, 421, 430, 431, 440, 441)	Lower compartment	Narrow range RTD's
TE68-1, -18, -24, -41, -43, -60, -65, -83 (413, 423, 433, 443)	Lower compartment	Wide range RTD's
NC41, 42, 43, 44	Lower compartment	Excore neutron detectors
H ₂ recombiners	Upper compartment	

PT68-322, -323, -334, -340 (455, 456, 457, 458)	Lower compartment	Pressurizer pressure transmitters
PT68-320, 335, 339 (459, 460, 461)	Lower compartment	Pressurizer level transmitters
PT68-66 (403)	Lower compartment	RCS wide range pressure transmitter
LT3-56, -111 (502, 504)	Lower compartment	Steam generator level transmitters (wide range)
FT1-3A&B, -10A&B, -21A&B, -28A&B (512, 513, 522, 532, 533, 542, 543)	Lower compartment	Steam flow transmitters
LT3-43, 98 (501, 503)	Lower compartment	Steam generator level transmitters (wide range)
LT3-38, -39, -42, -51, -52, -55, -93, -94, -97, -106, -107, -110, -111 (517, 518, 519, 527, 528, 529, 537, 538, 539, 547, 548, 549)	Lower compartment	Steam generator level transmitters (narrow range)

ENCLOSURE 4

ASSESSMENT OF THE CAPABILITY OF THE NORMAL CONTAINMENT COOLING

8. There are eight normal reactor building coolers, four in the lower compartment and four in the upper compartment. The lower compartment coolers have a capacity of eight million Btu/hr, and the upper compartment coolers provide an additional eight hundred thousand Btu/hr. This total capacity of 8.8 million Btu/hr is based on an affirmed atmospheric temperature of 327°F and river temperature of 83°F. The coolers are located above the maximum expected post-LOCA water level, are seismically qualified with full QA, and are supplied with ERCW. These coolers would be of some benefit in removing heat from hydrogen burns although no credit has been taken for them.

Several conditions tend to limit the effectiveness of the coolers:

- a. After unit 2 startup, offsite power and the new ERCW pumping station must be available or there will be insufficient ERCW to meet plant requirements for one unit in hot standby with a LOCA in the other unit.
- b. Present containment isolation logic isolates the ERCW lines to the coolers when the containment pressure exceeds three psig. This would require modifications for the coolers to be of benefit during degraded core events.

The CRDM coolers were also considered in assessing the capability of normal cooling systems. These coolers are located on the lower compartment floor and are therefore flooded early in a LOCA. It has been concluded that no credit can be taken for these coolers.

ESTIMATE OF CONTAINMENT SHELL TEMPERATURE DUE
TO HYDROGEN BURN IN THE LOWER COMPARTMENT

An estimate was made of the temperature rise in the containment shell due to hydrogen burning in the lower compartment. It was assumed that the gas will lose heat to the containment shell by radiation and convection and to the ice condenser. Due to the relatively low temperature of the gas in the dead-ended compartment, it was assumed that only the water vapor emitted and absorbed radiation. The containment shell will reradiate a portion of the energy it receives from the gas, some of which will be absorbed by the gas. Simple finite difference equations were used to represent the heat balances for the containment shell and gas for a time increment Δt . The gas and shell temperatures were updated at the end of each time step and the calculation repeated until thermal equilibrium was reached. For a single burn of 100 pounds of hydrogen in the lower compartment, the average temperature of a 1" thick steel containment shell increased by approximately 8°F . Assuming a similar temperature rise for each of the nine burns for the S₂O accident scenario, the mean temperature of the shell should increase by roughly 72°F . This corresponds to a total energy deposition in the wall of about 4.5×10^6 BTU.

The one inch thick containment shell was modelled as a one-dimensional slab. The total heat input of 4.5×10^6 BTU was added to the shell over a 200 second time interval which corresponds to a surface heat flux of about 5370 BTU/Hr-Ft^2 . The TAP-A computer program was utilized to compute the transient temperature distribution in the shell. The maximum temperature difference in the wall from inner surface to outer surface was approximately 21.4°F . The corresponding temperature difference from the inner surface of the shell to the center of the shell was roughly 15.7°F .

ESTIMATE OF CONTAINMENT SHELL TEMPERATURE DUE
TO HYDROGEN BURN IN LOWER COMPARTMENT: NO
ICE IN ICE CONDENSER AFTER FIRST TWO BURNS

An estimate was made of the temperature rise in the containment shell due to hydrogen burning in the lower compartment. The accident scenario is similar to that for the S₂D base case except that no ice remains in the ice condenser after the first two burns. The calculational assumptions are similar to those used in making the previous estimate of the shell temperature rise for the S₂D base case.

Since ice is available for the first two burns, it was assumed that the average temperature of 1" thick steel shell increased by 8°F for each burn as previously calculated. When no ice is available in the ice condenser the average shell temperature increases by approximately 17°F per burn. There are a total of seven burns, two with ice and five with no ice. The total temperature rise in the shell is estimated to be 101°F (2 X 8 + 5 X 17). This corresponds to a total energy deposition in the wall of about 6.3×10^6 BTU.


It was assumed that this amount of heat is added to the containment shell over a 200 second time interval which corresponds to a heat flux of approximately 7520 BTU/HR-FT². The TAP-A computer program was utilized to compute the transient temperature distribution in the shell. The maximum temperature difference in the shell from inner surface to outer surface was approximately 32°F. The corresponding temperature difference from the inner surface of the shell to the center of the shell was roughly 22°F.

BASE CASE PARAMETERS

1. INITIAL CONDITIONS:	VOLUMES TEMPERATURES PRESSURES ICE MASS ICE HEAT TRANSFER AREA	LOTIC
2. BURN PARAMETERS:	H ₂ FOR IGNITION H ₂ FOR PROPAGATION O ₂ FOR IGNITION O ₂ TO SUPPORT COMBUSTION FLAME SPEED	10 V/O* 10 V/O 5 V/O 0 V/O 6 FPS
3. AIR RETURN FANS:	NUMBER OF FANS CAPACITY OF EACH FAN	2 40000 CFM
4. SPRAY SYSTEM:	FLOW RATE TEMPERATURE DROP SIZE FALL TIME HEAT TRANSFER COEFFICIENT	6000 GPM 125 F 680 10 SEC 20 BTU/HR FT ² F
5. ICE CONDENSER DRAIN TEMPERATURE		32 F
6. BREAK RELEASE DATA		MARCH


* EXCEPT IN THE ICE CONDENSER

RECORD




TRIM SCID CASE 1 2 REV 1 SPANN BURN 100 PCT AT 10 U 9 GTPS 1-2450
PULSE 1

-45-




1967-10-18 00:00:00 1967-10-18 00:00:00
FILE (SECOND)



NETMA-

LENGHTH OF



CLASIX CAPABILITIES

1. VENT FROM UPPER COMPARTMENT
2. ICE CONDENSER
3. RECIRCULATION FAN
4. DOORS - LOWER INLET AND INTERMEDIATE
5. INDIVIDUAL REPRESENTATION OF O₂, H₂, N₂ AND H₂O
6. SATURATED AND SUPER-HEATED STEAM
7. SPRAYS
8. H₂, N₂ AND HEAT ADDITIONS
9. BREAK FLOW
10. BURN CONTROL

JUN 220 ODEET 15 LMW 1 2000 0000 0000 0000 0000 0000 0000

PAGE 1

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000

0000


0000

0000

0000

0000

0000




LEADERLINE 01 1C

MEPA-

BLOCK 01

RIDGE

PAGE 03



TUM 520 ONCE 1 2 REV 1 SPWY BLM 100 PCT AT 10 U • GPS 1-348N 100E 1

BURN CONTROL

1. v/o H₂ IGNITION
2. v/o H₂ PROPAGATION
3. o/o H₂ CONSUMED
4. v/o O₂ IGNITION
5. v/o O₂ SUPPORT COMBUSTION
6. PROPAGATION DELAY TIME
7. BURN TIME

MARCH

H₂O MASS RELEASE RATES

H₂O ENERGY RELEASE RATES

H₂ GENERATION RATES

H₂ TEMPERATURES

FISSION PRODUCT ENERGY RELEASE RATES

LOTIC

SUBCOMPARTMENT VOLUMES

SUBCOMPARTMENT TEMPERATURES

SUBCOMPARTMENT PRESSURES: O₂

N₂


STEAM

ICE MASS

ICE HEAT TRANSFER AREA

READY-


FRAME 41 F.41



TIN S2D C4C4S 2 FRAME 1 SPRAY EJECT 100 PCT AT 1000 CPS T=3.50 - KCF

READY-


FRAME 01



TUA S2D CASE 5 2 FRAME 1 SPRAY BURN 100 PCT AT 10 V 0 GIPS T+3480 -1°C

READY-


FRAME #2



TWO 52D CAGES 2 FRAME 1 SPRAY EJECT 100 FCT AT 10 U 0 GFS T-315.0 - ICE

READY


FRAME 03



TWO S2D CASES 2 FRAME 1 SPRAY BURN 100 FCT AT 10 0 0 FPS 1+3483 - ICE

READY-


FRAME 05 F.5



TUH SCD CASE 5 2 FRAME 1 SPRAY FLUSH 100 PCS AT 10 0 0 FPS T=3430 -1CE

READY-


FRAME 86 F.6



TWO 52D CASES 2 FOR 1 SPRAY BURN 100 FT AT 10 0 0 6FPS T+3480 -ICE

READY-

FRAME 07



TUA 520 CASES 2 FRN 1 SPRAY BURN 100 FCT AT 10 V 0 EPS T+3480 - ICE