Tera



NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

July 7, 1980

Docket No. 50-348

Mr. F. L. Clayton, Jr. Senior Vice President Alabama Power Company Post Office Box 2641

Birmingham, Alabama 35291

Dear Mr. Clayton:

We are continuing our review of the generic issue, "Adequacy of Station Electric Distribution System Voltages" for Farley Nuclear Plant, Unit No. 1. In our letter of August 8, 1979 we required verification by test to assure that analysis results are valid. We requested a description of the method of performing the verification and submittal of test results.

Your response dated December 11, 1979 provided a test description and results which verified the analysis for one electrical bus, the 4.16kV bus 1B. This test did not verify the analysis from startup transformer 1A to the 208V motor control center 1S.

You are requested to provide test results which validate voltage profiles of your December 11, 1979 letter. Your response is requested within 30 days of receipt of this letter or sooner if possible. This matter has been discussed previously during telecons between your Licensing Administrator, Mr. T. N. Epps, and our Project Manager, Mr. Ed Reeves.

Sincerely,

Operating Reactors Branch #1

Division of Licensing

cc: See next page

July 12, 1980

cc: Alan R. Barton
Executive Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Ruble A. Thomas, Vice President Southern Company Services, Inc. Post Office Box 2625 Birmingham, Alabama 35202

George F. Trowbridge, Esquire Shaw, Pittman, Potts and Trowbridge 1800 M Street, N.W. Washington, D. C. 20036

Mr. Robert A. Buettner, Esquire Balch, Bingham, Baker, Hawthorne, Williams and Ward Post Office Box 306 Birmingham, Alabama 35201

Edward H. Keiler, Esquire Keiler and Buckley 9047 Jefferson Highway River Ridge, Louisiana 70123

George S. Houston Memorial Library 212 W. Burdeshaw Street Dothan, Alabama 36303