


June 18, 1990

- 9:00 a.m. I. Introductory Remarks
A. NRC
B. Utilities
- 9:15 a.m. II. Accident Sequence Selection - Utility Presentation
A. Overview
B. Accident Sequence Event Trees & Probability Estimates
1. Sequence Event Trees for Z/IP
2. Data Sources (WASH-1400 & Others)
3. Initiating Event Probabilities
4. Mitigating Systems, Success Criteria & Probability of Failure on Demand
C. Containment Failure Modes and Fission Product Release
1. Identification of Modes and Basis for Failure Probability Estimates
2. Overall Accident Sequence Probabilities
3. Basis for Assignment of Overall Failure Sequences to Release Categories
4. Overall Accident Sequence Listing by Release Category
D. Risk Estimates
1. Short-Term Risk Tabulation by Release Category
2. Long-Term Risk Tabulation by Release Category
E. Results
1. Comparison of Zion, Indian Point & WASH-1400 PWR Risk Estimates
2. Comparison of Sequences to WASH-1400 PWR
a. Sequences Added and Eliminated re WASH-1400
b. Principal Design ~~Design~~ Differences re Dominant Sequences
3. Estimates of Risk Reduction Resulting from Interim Measures
4. Accident Sequence Ranking Relative to Risk
F. Conclusions
1. Methodology for Sequence Selection
2. Accident Sequence Ranking
3. Sequence Mitigation
4. Recommendations for Future Analysis
- 12:15 p.m. LUNCH
- 1:15 p.m. III. Long-Term Utility Probabilistic Risk Assessment - Utility Presentation
A. Scope of Study
B. Status
C. Schedule for Completion; Type of Results & Their Significance
- 2:15 p.m. IV. NRC Comments and Discussion of Dominant Accident Sequence Selection
- 4:00 p.m. V. Adjournment


8008140210

Slides presented by R. Henry - June 10, 1950


MECHANICAL DISPERSION
of
CORE MATERIAL



REACTOR BUILDING



DISPERJAL CALCULATIONS



$$U = \frac{3^4 \sqrt{g\sigma(\rho_F - \rho_G)}}{\rho_G}$$

$$W = \rho_G A_T U$$

$$G = \eta P_0 / \sqrt{RT}$$


$$A_V = W/G$$

$$D_F = \frac{3}{8} \frac{\rho_G U^2}{\rho_F G}$$


$$\tau_0 = \frac{RI}{P_0}$$

$$M_0 = \frac{V_V}{N_0}$$

$$\Delta\theta = \frac{M_0 Q}{W}$$



DISPERSAL POTENTIAL VERSE VESSEL
BREACH DIAMETER



REACTOR BUILDING

DISPERSED CONDITIONS

- AVAILABLE SURFACE AREA $\sim 800\text{m}^2$
- AMOUNT OF CORE DEBRIS $\sim 100,000\text{ kg}$
- BED POROSITY $\epsilon \sim 0.5$
- BED DEPTH $\sim 3\text{ cm}$

CONCLUSIONS

- MECHANICAL DISPERSIVE POTENTIAL IS LARGE AND PROBABLY DICTATES THE FINAL CORE DEPOSITION
- WATER IS AVAILABLE ON A CONTINUOUS BASIS ON ALL SURFACES WHERE SIGNIFICANT FUEL ACCUMULATION CAN OCCUR
- DISPERSED CORE IS COOLABLE AND NO SIGNIFICANT ATTACK OF THE CONCRETE OCCURS

Slides presented by Dee Walker, June 18, 1980

APPENDIX B: SYMBOLOGY

System Identification		System Failure
<u>Symbol</u>	<u>System</u>	<u>Symbol</u>
CSRS	Containment Spray Recirculation System	F
ECI(S)	Emergency Coolant Injection (System)	D
ECR(S)	Emergency Coolant Recirculation (System)	H
AFWS	Auxiliary Feedwater System	L
LPRS	Low Pressure Recirculation System	
HPIS	High Pressure Injection System	
LPIS	Low Pressure Injection System	
ACCS	Accumulator System	
RCS	Reactor Coolant System	
RHF	Residual Heat Removal System	
HPRS	High pressure recirculation system	
RWST	Refueling water storage tank	

2

SYMBOLOLOGY

Initiating Events

	<u>Symbol</u>
Large pipe break (6")	A
Small pipe break (2"-6")	S ₁
Small pipe break (1/2"-2")	S ₂
Interfacing check valve failure (To LPIS/LPRS) with blowdown outside containment	V
Transient (Loss of offsite AC power)	T

Loss of AC Power Events


	<u>Symbol</u>
Non-recovery of off-site power for about 1 hr	M
Loss of Onsite AC power for about 1 hr.	B
Non-recovery of any AC power for about 3 hrs.	B'
Successful recovery of some AC power within 3 hrs.	B''

Containment Failure Modes

	<u>Symbol</u>
Steam explosion in Reactor Vessel	α
Isolation leakage	β
Overpressure from Hydrogen burning	γ
Overpressure - generally (less hydrogen)	δ
Containment melt-through	ϵ

SHORT-TERM CORE MELT STUDY

PROCESS OVERVIEW



PRESENTATION OUTLINE

- IDENTIFICATION OF SEQUENCES
- PROBABILITY ESTIMATES
- FISSION PRODUCT RELEASES AND CONSEQUENCE CALCULATIONS
- RESULTS

ACCIDENT SEQUENCE IDENTIFICATION

- STARTING POINT
 - WASH-1400, APPENDIX 5, TABLE 3-14
 - CUTOFF PROBABILITY OF 1×10^{-6} / YEAR

- SEQUENCES ADDED
 - AHF
 - S₁HF
 - S₂HF

- SEQUENCES DELETED
 - S₂C
 - TML
 - TKQ
 - TKQM

ACCIDENT SEQUENCE SUMMARY

<u>SEQUENCE</u>	<u>INITIATING EVENT</u>	<u>FAILED FUNCTIONS</u>
AD	LARGE LOCA (A)	ECCS INJECTION (D)
AH	LARGE LOCA (A)	ECCS RECIRCULATION (H)
AHF	LARGE LOCA (A)	ECCS RECIRCULATION (H) + SPRAY RECIRCULATION (F)
S ₁ D	INTERMEDIATE LOCA (S ₁)	ECCS INJECTION (D)
S ₁ H	INTERMEDIATE LOCA (S ₁)	ECCS RECIRCULATION (H)
S ₁ HF	INTERMEDIATE LOCA (S ₁)	ECCS RECIRCULATION (H) + SPRAY RECIRCULATION (F)
S ₂ D	SMALL LOCA (S ₂)	ECCS INJECTION (D)
S ₂ H	SMALL LOCA (S ₂)	ECCS RECIRCULATION (H)
S ₂ HF	SMALL LOCA (S ₂)	ECCS RECIRCULATION (H) + SPRAY RECIRCULATION (F)
V	INTERFACING CHECK VALVE FAILURE (V)	
TMLBB'	TRANSIENT LOSS OF OFFSITE POWER (T)	ONSITE AC POWER + AUXILIARY FEEDWATER + LONG-TERM NON RECOVERY OF POWER
TMLBB''	TRANSIENT LOSS OF OFFSITE POWER (T)	ONSITE AC POWER + AUXILIARY FEEDWATER + RECOVERY OF SOME POWER

PROBABILITY TOPICS

- KEY DIFFERENCES FROM WASH-1400
- INITIATING EVENT PROBABILITIES
- COMPONENT FAILURE DATA
- SYSTEM FAILURE CALCULATION

SUMMARY OF WASH-1400 DIFFERENCES

1. CONTAINMENT FAILURE FROM STEAM EXPLOSION
 - REDUCED BY 10 FOR "A" SEQUENCES
 - REDUCED BY 100 FOR "S₁", "S₂", "TMLB" SEQUENCES
2. OPERATOR ERROR PROBABILITIES
 - ELIMINATE FAILURE TO SHIFT TO HOT LEG RECIRCULATION
 - REDUCE INJECTION-TO-RECIRCULATION ERROR PROBABILITY BY 10 FOR S₁HF AND S₂HF
3. INTERFACING CHECK VALVE CALCULATION
4. LOSS OF OFFSITE POWER PROBABILITY (ZION)
5. CONTAINMENT OVERPRESSURE FAILURE PROBABILITY
 - USED 0.1 FOR ALL SEQUENCES EXCEPT TMLB
6. DIESEL-GENERATOR COMMON MODE FAILURE
 - REDUCED PROBABILITY BY 100

INITIATING EVENT SUMMARY

<u>INITIATING EVENT</u>	<u>PROBABILITY</u>
LARGE LOCA (A)	1×10^{-4} /YEAR
INTERMEDIATE LOCA (S_1)	3×10^{-4} /YEAR
SMALL LOCA (S_2)	1×10^{-3} /YEAR
LOSS OF OFFSITE POWER (T)	0.04/YEAR (IP-2) 0.2/YEAR (ZION)
INTERFACING CHECK VALVE FAILURE (V)	2.8×10^{-10} /YEAR (IP-2) 7.2×10^{-8} /YEAR (ZION) 5.2×10^{-8} /YEAR (IP-3)

SOURCES OF COMPONENT FAILURE RATE DATA

- WASH-1400 GENERALLY

- EXCEPTIONS
 - DIESEL GENERATORS
 - GAS TURBINES (IP ONLY)
 - AUX FEEDWATER TURBINE (ZION)


- DETAILED DERIVATIONS IN APPENDIX A

MITIGATING SYSTEMS AND RELATED SEQUENCES



<u>SYSTEM</u>	<u>SEQUENCES</u>
LPIS	AD
ACCUMULATORS	AD, S ₁ D
HPIS	S ₁ D, S ₂ D
LPRS	AH, AHF
HPRS	S ₁ H, S ₁ HF, S ₂ H, S ₂ HF
CHECK VALVES	V
AFW	TMLB
ONSITE AC POWER	TMLB

FLUID SYSTEM UNAVAILABILITY ANALYSIS PROCEDURE

- PRODUCE SIMPLIFIED FLOW DIAGRAM
- ARRANGE COMPONENTS INTO GROUPS OR "BLOCKS"
- CONVERT FLOW DIAGRAM INTO A BLOCK DIAGRAM
- COMPUTE FAILURE PROBABILITY WITHIN EACH BLOCK
- DETERMINE THE COMBINATIONS OF BLOCK FAILURES WHICH RESULT IN SYSTEM FAILURE
- COMBINE BLOCK FAILURE PROBABILITIES TO ARRIVE AT SYSTEM FAILURE PROBABILITY



LPRS FLOW DIAGRAM



COMBINATION OF BLOCKS	PROBABILITY FORMULATION	RESULT	
		CSRS ALSO FAILS	CSRS DOES NOT FAIL
① AND ③	$3.6(-2) \times 3.6(-2)$	1.3×10^{-3}	
① AND ④	$3.6(-2) \times 2.8(-3)$		1×10^{-4}
② AND ③	$2.8(-3) \times 3.6(-2)$		1×10^{-4}
② AND ④	$2.8(-3) \times 2.8(-3)$		7.8×10^{-6}
P(LPRS AND CSRS) =		<u>1.3×10^{-3}</u>	
P(LPRS) =			<u>2×10^{-4}</u>

LPRS BLOCK DIAGRAM & FAILURE COMBINATIONS

EXAMPLE SEQUENCE PROBABILITY CALCULATIONS

SEQUENCE AH

$$p(\text{LPRS FAILURE}) = p(\text{EVENT H}) = 2 \times 10^{-4}$$

$$p(\text{LARGE LOCA}) = p(\text{EVENT A}) = 1 \times 10^{-4}$$

$$p(\text{SEQUENCE AH}) = \underline{\underline{2 \times 10^{-8}}}$$

SEQUENCE AHF

$$p(\text{LPRS} + \text{CSRS FAILURE}) = 1.3 \times 10^{-3}$$

$$p(\text{OPERATOR ERROR}) = \underline{3 \times 10^{-3}}$$

$$p(\text{EVENT HF}) = 4.3 \times 10^{-3}$$

$$p(\text{LARGE LOCA}) = p(\text{EVENT A}) = 1 \times 10^{-4}$$

$$p(\text{SEQUENCE AHF}) = \underline{\underline{4.3 \times 10^{-7}}}$$

COMPARISON OF CHECK VALVE FEATURES

PLANT FEATURE	ZION	IP-2	IP-3	WASH-1400
CHECK VALVE TEST CONNECTIONS PROVIDED?	YES	YES	YES	NO
PERIODIC TEST INTERVAL	NOT DONE(*)	15 MOS. (*)	9 MOS. (*)	—
LOW PRESSURE SYSTEM PIPING INSIDE CONTAINMENT?	NO	YES	YES	NO
CHECK VALVES ISOLATED BY NORMALLY CLOSED VALVE?	NO	YES	NO	NO
NUMBER OF PATHS TO LOW PRESSURE PIPING ISOLATED BY CHECK VALVES	4	4	4	3
NUMBER OF CHECK VALVES IN EACH PATH	3	2	2	2

(*) TESTING IS PRESENTLY PERFORMED AT EACH RCS PRESSURIZATION.




DIAGRAM OF INTERFACING CHECK VALVES

INTERFACING CHECK VALVE FAILURE PROBABILITY CALCULATION

The following calculation is based on the model and failure rates given in WASH-1400, Appendix V, Section 4.4, pp. V-43 and V-44.

Q₀ = Failure of one check valve pair, = 1/2 λ_Rλ_Lt²
one ordered double

Q₁ = Failure of one check valve pair, = 2Q₀ = λ_Rλ_Lt²
two ordered doubles

Q = Failure of any one of four check valve pairs = 4Q₁ = 4λ_Rλ_Lt²

V = Failure of any one of four check valve pairs with blowdown outside containment = 0.1Q = 0.4λ_Rλ_Lt²

λ_L = Failure rate from gross leakage = 2.6 x 10⁻³/yr

λ_R = failure rate from internal rupture = 8.8 x 10⁻⁵/yr

t = test interval = 9 mos = .75 yr.

p(V) = 0.4(2.6 x 10⁻³)(8.8 x 10⁻⁵)(.75)² = 5.2 x 10⁻⁸

CONTAINMENT FAILURE MODES

<u>FAILURE MODE</u>	<u>THIS STUDY</u>	<u>WASH-1400</u>
IN-VESSEL STEAM EXPLOSION (ALPHA)	10^{-3} , LARGE BREAKS 10^{-4} , SMALL BREAKS & TRANSIENTS	10^{-2}
FAILURE OF CONTAINMENT ISOLATION (BETA)	2×10^{-3}	2×10^{-3}
OVERPRESSURE FAILURE (GAMMA + DELTA)	0.1	0.1 TO 0.2 FOR NO SPRAY CASES 0.8 FOR TMLB $< 10^{-2}$ OTHER CASES
MELT THRU (EPSILON)	CASE 1: RESIDUAL ASSUMING TOTAL FAILURE PROBABILITY OF 1.0 CASE 2: 10^{-2}	RESIDUAL ASSUMING TOTAL FAILURE PROBABILITY OF 1.0

CATEGORIZATION OF SEQUENCES INTO RELEASE CATEGORIES

1a	1b		2	3	5	6	7
	STEAM EXPLOSION + NO SPRAY	HIGH PRESSURE					
AHF	S ₁ HF S ₂ HF TMLBB'(IP)	AHF S ₁ HF S ₂ HF V TMLBB'(IP)	AD AH S ₁ D S ₂ D S ₁ H S ₂ H TMLBB'(ZION) TMLBB''	AD AH S ₁ D S ₂ D S ₁ H S ₂ H TMLBB'(ZION) TMLBB''	AHF S ₁ HF S ₂ HF TMLBB'(IP)	AD AH S ₁ D S ₂ D S ₁ H S ₂ H TMLBB'(ZION) TMLBB''	

COMPARISON OF ACCIDENT
SEQUENCE PROBABILITIES

SEQUENCE	PROBABILITY (PER YEAR)			
	ZION	IP-2	IP-3	WASH-1400
AD	5×10^{-7}	6×10^{-7}	5×10^{-7}	2×10^{-6}
AH	2×10^{-8}	1×10^{-7}	2×10^{-9}	1×10^{-6}
AHF	4×10^{-7}	3×10^{-7}	3×10^{-7}	1×10^{-10}
S ₁ D	5×10^{-7}	2×10^{-6}	1×10^{-6}	3×10^{-6}
S ₁ H	1×10^{-6}	1×10^{-6}	1×10^{-6}	3×10^{-6}
S ₁ HF	5×10^{-7}	1×10^{-7}	1×10^{-7}	4×10^{-10}
S ₂ D	5×10^{-7}	5×10^{-6}	4×10^{-6}	9×10^{-6}
S ₂ H	4×10^{-6}	4×10^{-6}	4×10^{-6}	6×10^{-6}
S ₂ HF	2×10^{-6}	4×10^{-7}	4×10^{-7}	1×10^{-9}
S ₂ C	N/A	A	N/A	2×10^{-6}
V	7×10^{-8}	3×10^{-10}	5×10^{-8}	4×10^{-6}
TMLBB'	1×10^{-8}	8×10^{-9}	8×10^{-9}	3×10^{-6}
TMLBB''	1×10^{-8}	8×10^{-9}	8×10^{-9}	3×10^{-6}

22

TABLE 3-1
CONTAINMENT FAILURE MODE PROBABILITIES
AND RELEASE CATEGORIES FOR THE
DOMINANT ACCIDENT SEQUENCES

SEQUENCE	CONTAINMENT FAILURE PROBABILITY AND (RELEASE CATEGORY)					
	α	β	γ	δ	ϵ (NOTE 1)	
					CASE 1	CASE 2
AD	$10^{-3}(3)$	$2 \times 10^{-3}(5)$	0.1(5)	0	0.9(7)	.01(7)
AH	$10^{-3}(3)$	$3 \times 10^{-3}(5)$	0.1(5)	0	0.9(7)	.01(7)
AHF	$10^{-3}(1)$	$3 \times 10^{-3}(5)$	0.1(2)	0	0.9(6)	.01(6)
S ₁ D	$10^{-4}(3)$	$2 \times 10^{-3}(5)$	0.1(5)	0	0.9(7)	.01(7)
S ₁ H	$10^{-4}(3)$	$1.67 \times 10^{-3}(5)$	0.1(5)	0	0.9(7)	.01(7)
S ₁ HF	$10^{-4}(1)$	$1.67 \times 10^{-3}(5)$	0.1(2)	0	0.9(6)	.01(6)
S ₂ D	$10^{-4}(3)$	$2.2 \times 10^{-3}(5)$	0.1(5)	0	0.9(7)	.01(7)
S ₂ H	$10^{-4}(3)$	$1.67 \times 10^{-3}(5)$	0.1(5)	0	0.9(7)	.01(7)
S ₂ HF	$10^{-4}(1)$	$1.67 \times 10^{-3}(5)$	0.1(2)	0	0.9(6)	.01(6)
V						
TMLBB	$10^{-4}(3)$.24(5)	0	.76(7)	.76(7)
TMLBB' (Zion)	$10^{-4}(3)$.24(5)	.56(5)	.2(7)	.2(7)
TMLBB' (I.Point)	$10^{-4}(1)$.24(2)	.56(2)	.2(6)	.2(6)

Note (1)

Case 1: $P(\epsilon) = 1 - \sum p(\text{others})$

Case 2: $P(\epsilon) = .01$, except for TMLB sequences. For TMLB sequences, $P(\epsilon)$ is the same as in Case 1.

SUMMARY OF PROBABILITY ESTIMATES: INDIAN POINT - 3

Sequence \ Release Category	1	2	3	4	5	6	7
AD			5.4(-10) α		1.1(-9) β 5.4(-8) γ		4.9(-7) ϵ
AH			1.6(-12) α		4.8(-12) β 1.6(-10) δ		1.4(-9) ϵ
AHF	3.0(-10) α	3.0(-8) γ			9.0(-10) β	2.7(-7) ϵ	
S ₁ D			1.4(-10) α		2.8(-9) β 1.4(-7) δ		1.3(-6) ϵ
S ₁ H			1.2(-10) α		2.0(-9) β 1.2(-7) δ		1.1(-6) ϵ
S ₁ HF	1.1(-11) α	1.1(-8) γ			1.8(-10) β	1.0(-7) ϵ	
S ₂ D			3.6(-10) α		7.9(-9) β 3.6(-7) δ		3.2(-6) ϵ
S ₂ H			4.0(-10) α		6.7(-9) β 4.0(-7) δ		3.6(-6) ϵ
S ₂ HF	3.6(-11) α	3.6(-8) γ			6.0(-10) β	3.2(-7) ϵ	
V		5.2(-8)					
TMLBB			8.0(-13) α		1.9(-9) γ		6.1(-9) ϵ
TMLBB	8.0(-13) α	1.9(-9) γ 4.5(-9) δ				1.6(-9) ϵ	
Total Category Probability	3.5(-10)	1.4(-7)	1.6(-9)		1.1(-6)	6.9(-7)	9.7(-6)

SUMMARY OF RELEASE CATEGORY
PROBABILITY ESTIMATES (FOR CASE 1)


RELEASE CATEGORY PLANT	1	2	3	4	5	6	7
INDIAN POINT - 2	3.5(-10)	8.5(-8)	1.9(-9)	-	1.3(-6)	7.0(-7)	1.1(-5)
INDIAN POINT - 3	3.5(-10)	1.4(-7)	1.6(-9)	-	1.1(-6)	6.9(-7)	9.7(-6)
ZION	6.4(-10)	3.2(-7)	1.2(-9)	-	6.8(-7)	2.2(-6)	6.1(-6)
WASH-1400 PWR	2.8(-8)	4.6(-6)	2.3(-6)	-	3.8(-8)	1.4(-7)	2.9(-5)

10
4

PRINCIPAL DESIGN DIFFERENCES
 IMPORTANT IN THE DOMINANT SEQUENCES

DESIGN FEATURE	PLANT APPLICABILITY			
	ZION	IP-2	IP-3	WASH-1400 PWR
DIESEL SPRAY PUMP	X			
CONTAINMENT FAN COOLERS	X	X	X	
PARALLEL LOW PRESSURE RECIRC. SUBSYSTEMS		X	X	
THREE VS TWO DIESELS	X	X	X	
GAS TURBINES		X	X	
CHECK VALVE TEST CONNECTIONS	X	X	X	
CTMT. SPRAY RECIRC. SEPARATE FROM ECCS RECIRC.				X

PROBABILITY PER REACTOR YEAR



WASH-200 AT INDIAN POINT SITE

WASH-1400 AT ZION SITE

WASH-1400

ZION & INDIAN POINT PLANTS AT THEIR OWN SITES (BASE PLANTS WITH NO CHANGES & NO CREDIT FOR STEAM EXPLOSION TECHNOLOGY)

CONSEQUENCE

SUMMARY OF MAN-REM CONSEQUENCE
AND RISK RESULTS BY RELEASE CATEGORY

		1a	1b	2	3	5	6	7
INDIAN PT. 2	Consequence Per Event	4.8(7)	2.1(7)	2.9(7)	3.0(7)	2.9(6)	2.7(5)	4.4(3)
	Risk Per Year	1.4(-2)	1.1(-3)	2.5	5.7(-2)	3.8	1.9(-1)	4.8(-2)
INDIAN PT. 3	Consequence Per Event	4.8(7)	2.1(7)	2.9(7)	3.0(7)	2.9(6)	2.7(5)	4.4(3)
	Risk Per Year	1.4(-2)	1.0(-3)	4.1	4.8(-2)	3.2	1.9(-1)	4.3(-2)
ZION	Consequence Per Event	1.8(7)	1.2(7)	1.6(7)	1.9(7)	2.6(6)	3.2(5)	5.9(3)
	Risk Per Year	7.7(-3)	2.5(-3)	5.1	2.3(-2)	1.8	0.7	3.6(-2)
WASH-1400	Consequence Per Event	2.8(6)		3.1(6)	1.4(6)	7.0(4)	7.5(3)	1.3(2)
	Risk Per Year	7.8(2)		1.4(1)	3.2	2.7(-3)	1.1(-3)	3.8(-3)

SUMMARY

IMPORTANT CONTRIBUTORS TO RISK FOR INDIAN POINT & ZION

	<u>TYPE OF SEQUENCE - CONTAINMENT FAILURE MODE CONTRIBUTION</u>	<u>REPRESENTATIVE SEQUENCES</u>
MAJOR	CONTAINMENT OVERPRESSURE FAILURE WITHOUT SPRAYS. FAILURE RESULTING FROM PRESSURE SPIKES (HYDROGEN BURN OR RAPID STEAM GENERATION)	AHF-GAMMA S ₁ HF-GAMMA
INTERMEDIATE	CONTAINMENT OVERPRESSURE FAILURES WITH SPRAYS INTERFACING CHECK VALVE FAILURES (PERHAPS) TMLB' WITH OVERPRESSURE FAILURE (PERHAPS)	AH-GAMMA AD-GAMMA S ₁ D-GAMMA S ₂ D-GAMMA V(?) TMLB(?)
MINOR	INTERFACING CHECK VALVE FAILURES (PERHAPS) TMLB' WITH OVERPRESSURE FAILURE (PERHAPS) ALL STEAM EXPLOSION SEQUENCES ALL CONTAINMENT ISOLATION FAILURE	V(?) TMLB(?) ALPHA MODE ALPHA MODE

13
(1)

NRC SEQUENCES FOR Z/IP MITIGATING SYSTEMS DESIGN

SEQUENCE

AB-BURN	LARGE BREAK, LOSS OF AC POWER EARLY AND RAPID HYDROGEN BURN	<ul style="list-style-type: none">o LOW PROBABILITYo UNNECESSARILY HIGH AMBIENT PRESSURE AT TIME OF BURNo UNNECESSARILY CONSERVATIVE DESIGN CONDITIONS
S ₂ D-BURN	SMALL BREAK, LOSS OF INJECTION, RAPID HYDROGEN BURN	<ul style="list-style-type: none">o REALISTIC SEQUENCEo S₂HF SHOULD ALSO BE CONSIDERED
S ₂ C	SMALL BREAK, LOSS OF CONTAINMENT SPRAY INJECTION	<ul style="list-style-type: none">o NOT AN APPROPRIATE SEQUENCE FOR IP AND ZION
A-VENT	LARGE BREAK, LOSS OF CONTAINMENT INTEGRITY	<ul style="list-style-type: none">o NOT A CORE MELT SEQUENCE
TMLB' TMLB''	LOSS OF AC POWER, LOSS OF HEAT SINK, LONG-TERM POWER LOSS (B') OR SOME POWER RECOVERY (B'')	<ul style="list-style-type: none">o INTERMEDIATE - LOW RISK CONTRIBUTIONo BOTH PROBABILITY AND MITIGATION SHOULD BE CONSIDERED.o UTILIZED IN PRESENT SYSTEM EFFECTIVENESS EVALUATIONS

SUGGESTED SEQUENCESFORDESIGN

LARGE BREAK

AD OR AHF

SMALL BREAK

S₁D OR S₂DS₁H OR S₁HF

TRANSIENTS

DO NOT UTILIZE AS PART OF DESIGN

BASIS BECAUSE OF SMALL RISK CONTRIBUTION

Meeting 5

Distribution:

Docket Files
RSB Rdg. Files
D. Ross
L. Rubenstein
P. Check
T. Novak
T. Speis
J. Meyer
J. Long
J. Carter
E. Fenstermacher
A. Marchese
S. Soffer
R. DiSalvo
H. Denton
E. Case
D. Eisenhut
R. Mattson
S. Hanauer
W. Russell
J. Olshinski
G. Zech
T. Murley
R. Budnitz
L. Olshan
E. Reeves
C. Kelber
M. Silberberg
S. Acharya
R. Sherry
F. Rowsome
M. Picklesimer
W. Butler
R. Benero
W. Houston
Local PDR
NRC PDR (2)

S. Varga
H. Polk
TERA
NSIC
NRR Rdg. File
ORB-1 R/F
G. Quittschreiber, ACRS
P. Williams
W. Kastenberg, ACRS
F. Schauer
D. Jeng
P. Kuo