

Central files



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76012

23 JUL 1980

Docket No. 99900510/80-01


United Engineers & Constructors, Inc.
Attn: Mr. R. A. Curnane
Vice President, Project Support Operations
30 South 17th Street
P. O. Box 8223
Philadelphia, PA 19101

Gentlemen:

Thank you for your letter of July 2, 1980 in response to our letter dated June 4, 1980. We acknowledge that there was an inaccurate statement in our report and that the report should have stated that one (1) specification, 9779-101, was found with an incorrect ARS specified for 24 individual pieces of equipment.

We have no further questions concerning your responses at this time. We will review your corrective and preventive actions during a future inspection.

Sincerely,


Uldis Potapovs, Chief
Vendor Inspection Branch

8008140 416