

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N Y J A F I | 2 | 0 0 - 0 0 0 0 - 0 0 0 | 3 | 4 1 1 1 1 | 4 | _____ | 5 | _____
7 8 9 14 15 25 28 57 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
01 | REPORT SOURCE | L | 6 | 0 5 0 0 0 3 3 3 | 7 | 0 1 7 | 1 4 8 | 0 | 8 | 0 8 1 2 8 | 0 | 9 | _____
7 8 50 51 58 59 74 75 80
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During normal shutdown functional test of hydraulic snubbers to satisfy Technical
03 | Specification 4.6.I.3 revealed two (2) snubbers which failed the specified lockup
04 | and bleed-rate values. Both snubbers were replaced with operable spares. The event
05 | did not represent a significant hazard to the public health and safety.
06 | _____
07 | _____
08 | _____

09 | SYSTEM CODE | C B | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | F | 13 | COMPONENT CODE | S U P I O R I T | 14 | COMP. SUBCODE | D | 15 | VALVE SUBCODE | Z | 16 |
7 8 9 10 11 12 13 18 19 20
EVENT YEAR | 8 0 | 21 22 | SEQUENTIAL REPORT NO. | 0 6 1 | 24 26 | OCCURRENCE CODE | / | 27 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32
17 | LER/RO REPORT NUMBER | 8 0 | 21 22 | SHUTDOWN METHOD | Z | 36 | HOURS | 0 0 0 0 | 37 40 | ATTACHMENT SUBMITTED | N | 41 | NPRD-4 FORM SUB. | Y | 42 | PRIME COMP. SUPPLIER | X | 43 | COMPONENT MANUFACTURER | X 9 9 9 | 44 47
ACTION TAKEN | X | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 36 | HOURS | 0 0 0 0 | 37 40 | ATTACHMENT SUBMITTED | N | 41 | NPRD-4 FORM SUB. | Y | 42 | PRIME COMP. SUPPLIER | X | 43 | COMPONENT MANUFACTURER | X 9 9 9 | 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Failure is attributed to normal wear and tear in each case. Overhaul (parts
11 | replacement) and adjustment restored both to operable status. One snubber,
12 | manufactured by Grinnel (NPRD Code G-255) was supplied by the NSSS vendor. The
13 | other was made by Bergen-Patterson (NPRD Code B209) and supplied by the Architect-
14 | Engineer.
7 8 9 30

15 | FACILITY STATUS | G | 28 | % POWER | 0 0 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Surveillance | 32
7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED OF RELEASE | Z | 33 | CONTENT | 7 | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36
7 8 9 10 11 44 45 80

17 | PERSONNEL EXPOSURES NUMBER | 0 0 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39
7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER | 0 0 0 | 40 | DESCRIPTION | NA | 41
7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43
7 8 9 10 80

20 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45
7 8 9 10 80

8008180452 W. Verne Childs PHONE: 315-342-3840
7 8 9 58 59 80