

NRC ADL



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

July 21, 1980

Docket No. 50-29

Mr. Robert H. Groce  
Licensing Engineer  
Yankee Atomic Electric Company  
20 Turnpike Road  
Westboro, Massachusetts 01581

Dear Mr. Groce:

The Commission has issued the enclosed Amendment No. 61 to Facility Operating License No. DPR-3 for the Yankee Nuclear Power Station (Yankee Rowe). The amendment is in response to your application dated September 24, 1979.

The amendment deletes the technical specifications for secondary water chemistry and incorporates a new license condition in the license, paragraph 2.C(5), for implementation of a secondary water chemistry monitoring program which inhibits steam generator tube degradation.

We found it necessary to modify your proposed license condition. This change was discussed with and agreed to by your staff.

Copies of our related Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

*Dennis M. Crutchfield*  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosures:

- 1. Amendment No. 61 to DPR-3
- 2. Safety Evaluation
- 3. Notice of Issuance

cc w/enclosures:  
See page 2

8008190 104

P

Mr. James A. Kay

- 2 -

July 21, 1980

CC w/enclosures:  
Mr. James E. Tribble, President  
Yankee Atomic Electric Company  
25 Research Drive  
Westborough, Massachusetts 01581

Greenfield Community College  
1 College Drive  
Greenfield, Massachusetts 01301

Chairman  
Board of Selectmen  
Town of Rowe  
Rowe, Massachusetts 01367

Energy Facilities Siting Council \*  
14th Floor  
One Ashburton Place  
Boston, Massachusetts 02108

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection  
Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection  
Agency  
Region I Office  
ATTN: EIS COORDINATOR  
JFK Federal Building  
Boston, Massachusetts 02203

\*w/incoming