



Nebraska Public Power District

bcc to DAC:ADM:
CENTRAL FILES
PDR:HQ
LPDR
TIC
NSIC

P.O.

68321

June 17, 1980

Mr. Karl V. Seyfrit, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region IV
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76011

Subject: Response to IE Bulletin No. 80-10
Contamination of Nonradioactive System and
Resulting Potential For Unmonitored, Uncontrolled
Release of Radioactivity to Environment

Dear Mr. Seyfrit:

This letter is written in response to the subject IE Bulletin and addresses action items (1) and (2) of the bulletin.

- (1) A review of systems which are nonradioactive but have the potential of becoming contaminated by interfacing with radioactive systems was conducted in response to IE Circular 77-14. The present design of these systems is unchanged from the time when the review was conducted, therefore, this review is still applicable.
- (2) Systems in which the potential for contamination exists have been added to the routine sampling and analysis program to identify any contamination.

System identification and sampling information is available on site for subsequent NRC review.

Sincerely,

J. M. Pilant
Director of Licensing
and Quality Assurance

JMP:PJB:cg

8008200139

Q