



MISSISSIPPI POWER & LIGHT COMPANY
Helping Build Mississippi
P. O. BOX 1640. JACKSON, MISSISSIPPI 39205

Victa Stello

NUCLEAR PRODUCTION DEPARTMENT

August 13, 1980

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Units 1 and 2
Docket Nos. 50-416/417
File 0260/15525/15526
PRD-80/18, Status Report #2,
Improper Installation of High
Pressure Core Spray Diesel
Generator Panels
AECM-80/187

Reference: AECM-80/97, dated May 9, 1980

On April 11, 1980, Mississippi Power & Light Company notified Mr. F. Cantrell of your office of a Potentially Reportable Deficiency (PRD) at the Grand Gulf Nuclear Station construction site. The deficiency concerns the incorrect installation of a control panel (1H22-P118) and a protective relay panel (1H22-P028).

The NSSS supplier has been requested to analyze and evaluate the panel installation to determine affects on safety. Corrective actions will be based on the results of this evaluation.

We expect to provide a final report and determination of reportability by December 10, 1980.

Yours truly,

J. P. McGaughy, Jr.
Assistant Vice President,
Nuclear Production

ATR:mt

*B019
S 1/0*

8008200280

Member Middle South Utilities System

MISSISSIPPI POWER & LIGHT COMPANY

Mr. J. P. O'Reilly
NRC

AECM-80/187
Page 2

cc: Mr. N. L. Stampley
Mr R. B. McGehee
Mr. T. B. Conner

Mr. Victor Stello, Director
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

bcc: Dr. D. C. Gibbs
Mr. N. L. Stampley
Mr. J. P. McGaughy
Mr. J. N. Ward
Mr. J. W. Yelverton
Mr. A. Zaccaria
Mr. L. F. Dale
Mr. C. K. McCoy
Mr. T. H. Cloninger
Mr. R. A. Ambrosino
Mr. C. L. Tyrone
Mr. M. Hunt
Mr. A. G. Wagner
PRD File
File