



**LOUISIANA**  
**POWER & LIGHT**

142 DELARONDE STREET  
P. O. BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 366-2345

MIDDLE SOUTH  
UTILITIES SYSTEM

August 22, 1980

D. L. ASWELL  
Vice President-Power Production

LPL 14934  
3-S15

Mr. Albert Schwencer, Chief  
Director of Nuclear Reactor Regulation  
Licensing Branch No. 2  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

SUBJECT: Waterford 3 SES  
Docket No. 50-382  
Response to Information Request on Category I  
Masonry Walls

REFERENCE: NRC letter from S. A. Varga to D. L. Aswell  
dated April 21, 1980

Dear Mr. Schwencer:

The above reference inquired if there are any concrete masonry walls used to support Seismic Category I piping/equipment at Waterford 3. Our response to this inquiry is that there are no Seismic Category I masonry (concrete block) walls on Waterford 3; therefore, no Seismic Category I piping/equipment supports are attached by any means to any of the block walls in the Nuclear Island structure.

Yours very truly,

D. L. Aswell

DLA/RWP/ddc

cc: E. Blake, W. M. Stevenson

*Boo's 10*

8008270 358