



**Northern Indiana Public Service Company**

General Offices / 5265 Hohman Avenue / Hammond, Indiana 46325 / Tel.: 853-5200 (219)

EUGENE M. SHORB  
FIRST VICE PRESIDENT

August 11, 1980

Mr. James G. Keppler  
Regional Director  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 50137

RE: NRC IE Bulletin 80-20, "Failures of  
Westinghouse Type W-2 Spring Return  
to Neutral Control Switches"

Dear Mr. Keppler:

This is to inform you that Northern Indiana Public Service Company (NIPSCO) has not and will not use any Westinghouse Type W-2 spring return to neutral control switches susceptible to the failures described in the subject IE Bulletin in its Bailly Generating Station Nuclear-1 safety-related applications.

Very truly yours,

EMS:jrb

cc: U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Division of Reactor Construction Inspection  
Washington, D.C. 20555

AUG 12 1980

8008280083

Q