

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

August 26, 1980

TVA BFPN TS 147

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Denton:

In the Matter of the ) Docket No. 50-296  
Tennessee Valley Authority )

In accordance with the provisions of 10 CFR Part 50.59, we are enclosing 40 copies of a requested expedited amendment to license DPR-68 to change the technical specifications of the Browns Ferry Nuclear Plant unit 3 (Enclosure 1). The proposed technical specifications clarify requirements for the residual heat removal service water system and add a specification which allows the standby coolant supply capability to be inoperable for a period not to exceed ten days. Also enclosed is the justification for the proposed changes (Enclosure 2).

In accordance with the requirements of 10 CFR Part 170.22, we have determined this proposed amendment to be Class III. This classification is based on the fact that the proposed amendment involves a single safety issue which does not involve a significant hazard consideration. The remittance for \$4,000 is being wired to the NRC, Attention: Licensing Fee Management Branch.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*L. M. Mills*

L. M. Mills, Manager  
Nuclear Regulation and Safety

Subscribed and sworn to before  
me this 26<sup>th</sup> day of Aug. 1980.

*Bryant M. Lowery*  
Notary Public

My Commission Expires 4/4/82

Enclosures  
cc: See page 2

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

8009020069\*

P

Mr. Harold R. Denton

August 26, 1980

cc (Enclosures):

Mr. Charles R. Christopher  
Chairman, Limestone County Commission  
P.O. Box 188  
Athens, Alabama 35611

Dr. Ira L. Myers  
State Health Officer  
State Department of Public Health  
State Office Building  
Montgomery, Alabama 36104