

VOLUME 9A  
IMPLEMENTING PROCEDURES-5D  
BIG ROCK POINT NUCLEAR PLANT  
SITE EMERGENCY PLAN

PROCEDURE TO DETERMINE EXTENT OF CORE  
DAMAGE (FOR 0% TO 100% CORE MELTDOWN)  
Procedure 5D

1.0 PURPOSE

1.1 To provide a method for estimating the degree of core damage during accident conditions. If radiation levels are low enough, sampling of core spray heat exchanger water may be performed (per EPIP 5E) for determining up to 10% core meltdown.

2.0 METHOD

2.1 The degree of core damage will be estimated using the ionization chamber readout (in the air compressor room) and the attached graphs (Attachments 1 and 2) of dose rate versus time.

3.0 TECHNICAL SPECIFICATIONS AND OTHER REQUIREMENTS

3.1 Letter from D P Hoffman to D K Ziemann, dated December 27, 1979; Big Rock Point Plant - Requirements Resulting from Review of Three Mile Island 2 Accident. Actions taken in response to Section 2.1.8.a, Page 21.

3.2 The containment monitor shall be calibrated at least quarterly.

4.0 SPECIAL EQUIPMENT

4.1 A high range ionization chamber (located in the cable penetration room, approximately four feet off the floor and six feet from the containment).

4.2 A local readout with range switch (located in the air compressor room).

June 10, 1980

5D-1

Rev 0

pr0480-0053d-97

8009020 343

VOLUME 9A  
IMPLEMENTING PROCEDURES-5D  
BIG ROCK POINT NUCLEAR PLANT  
SITE EMERGENCY PLAN

4.3 Graphs of ionization chamber readout for 100% fuel failure in R/h versus time (Attachments 1 and 2).

5.0 PRECAUTIONS AND LIMITATIONS

5.1 Radiological surveys shall be conducted as necessary to ensure the radiation limits of 10 CFR 20 are not exceeded during the performance of this procedure.

6.0 PROCEDURE

6.1 In the air compressor room, record the following ionization chamber information on the Extent of Core Damage Data Sheet (Attachment 3):

6.1.1. Date (Location 1).

6.1.2. Time (Location 2).

6.1.3. Initials of person obtaining information (Location 3).

6.1.4. Reading of ionization chamber (Location 4).

NOTE: This instrument reads in KR/h. Multiply KR/h by 1,000 to obtain R/h.

6.1.5. Time elapsed from  $t=0$  (time elapsed since reactor trip) (Location 5).

6.2 Using the appropriate graph of R/h with 100% fuel failure versus time - post accident (Attachment 1 or 2), record on Attachment 3 (Location 6) the R/h value at the time elapsed since reactor trip ( $t=0$  at reactor trip).

6.3 Divide Step 6.1.4 by Step 6.2 and multiply by 100 to determine the percent of core damage. Record this on Attachment 3 (Location 7).

VOLUME 9A  
IMPLEMENTING PROCEDURES-5D  
BIG ROCK POINT NUCLEAR PLANT  
SITE EMERGENCY PLAN

6.4 Example:

An accident has occurred that requires an estimation of the percentage of core damage.

- a. The ionization chamber readout is  $1 \times 10^4$  R/h at one hour after  $t=0$  (Step 6.14).
- b. The attached graphs give a value of  $1.7 \times 10^4$  R/h at one hour from  $t=0$  (Step 6.2).
- c. 
$$\frac{1.0 \times 10^4 \text{ R/h}}{1.7 \times 10^4 \text{ R/h}} = 0.59$$
$$(0.59)(100) = 59\% \text{ (Step 6.3)}$$

The extent of core damage is 59%.

Dose Rate (R/hr)

vs

Time after Shutdown (Hrs)

for  
100% Fuel Failure


$10^5$

(R/hr)

Dose Rate

$10^4$

$10^3$




EMERGENCY PLAN IMPLEMENTING PROCEDURE 5D,  
ATTACHMENT 5D-2

Dose Rate (R/hr)

VS

Time after Shutdown (Days)

100% Fuel Failure



June 10, 1980<sup>5</sup>

10 15 20 25 30  
Time Post-accident (Days)

SD-5

Rev 0

IMPLEMENTING PROCEDURE 5D, ATTACHMENT 5D-3

EXTENT OF CORE DAMAGE DATA SHEET

Date 1	Time 2	Initial 3	Monitor Reading (R/h) 4	Time from t=0 5	Graph Reading (R/h) 6	$\left( \frac{\text{Step 6.1.4}}{\text{Step 6.2}} \right) 100 = \% \text{ Core Damage}$

Calculated by \_\_\_\_\_  
 Reviewed by Plant Health Physicist \_\_\_\_\_  
 Reviewed by Site Emergency Director \_\_\_\_\_