LICENSEE EVENT REPORT
CONTROL BLOCK:
0 1 N Y J A F 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 57 CAT 58 5
CON'T O 1 8 REPORT L 6 0 5 0 0 10 13 13 13 7 0 8 0 5 8 0 8 0 8 0 8 0 9
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) During normal shutdown, while conducting Instrument Surveillance Procedure F-ISP-12
o 3 and 12-1, HPCI and RCIC steam line low pressure switches 23-PS-68A and 13-PS-87B
0 4 were found set 9.5 and 12.0 PSIG higher than the 100 PSIG limit of TS Table 3.2-2.
Redundant switches (6 total) were satisfactory preventing any loss of function.
0 6 Reactor was shutdown and hazard was not significant.
0 7
0 8 60
7 8 9 SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBCODE SUBCODE
S F 11 E 12 E 13 I N S T R U (14) S (15) Z (16) 9 10 11 12 SEQUENTIAL OCCURRENCE REPORT REVISION
17 REPORT NUMBER 21 22 23 24 26 27 28 29 30 31 32
ACTION FUTURE OMPLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED FORM SUB. PRIME COMP. COMPONENT MANUFACTURER E 18 Z 19 Z 20 Z 21
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) [1 0] Cause is Instrument drift. Both instruments calibrated and returned to service
in operable status later on the same day. No additional action is required.
13
7 8 9 FACILITY STATUS % POWER CTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32
STATUS STATUS OF POWER OF CTHER STATUS OF DISCOVERY DESCRIPTION (32) NA B (31) Surveillance 80
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) 1 6 Z (33) Z (34) NA
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
1 7 0 0 0 37 Z 38 NA 2 8 9 PERSONNEL INJURIES 13 80
NUMBER DESCRIPTION NA NA
LOSS OF OR DAMAGE TO FACILITY 43
1 9 Z (42) NA NRC USE ONLY NRC USE ONLY
2 0 N 44 DESCRIPTION 45 NA NA 68 69 80
7 8 9 10