NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N Y J A F 1 (2) | 0 0 - 0 0 0 0 - 0 0 0 (3) | 4 1 1 1 1 (4) | (5)

7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 3 3 (7) | 0 8 0 6 8 0 (8) | 0 8 2 9 8 0 (9)

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal cold shutdown, while conducting Instrument Surveillance Procedure

03 F-ISP-15 to satisfy TS 4.6.D, drywell equipment drain sump pump flow transmitter,

04 the instrument was found out of tolerance 4.37 percent low compared to required 2

05 percent accuracy. The instrument was not required to be operable as the reactor

06 was in the cold condition.

07

08

7 8 9 80

09 | SYSTEM CODE C I (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE T (15) | VALVE SUBCODE Z (16)

7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER | EVENT YEAR 8 0 | — | SEQUENTIAL REPORT NO. 0 6 8 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER G 0 8 0 (26)

33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Drift was the cause of the out of tolerance instrument. Following calibration on the

11 same day, instrument was returned to service in an operable status. Surveillance was

12 also increased from once/month to once/week until repeated satisfactory performance

13 was demonstrated. No additional action is required.

14

7 8 9 80

15 | FACILITY STATUS G (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance

7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

7 8 9 10 11 44 45 80

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

7 8 9 10 80

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

7 8 9 68 69 80

8009020403

NAME OF PREPARER W. Verne Childs PHONE: 315-342-3840

GPO 917-926