

August 6, 1980

In reply, please
refer to LAC-7073

DOCKET NO. 50-409

Director of Nuclear Reactor Regulation
ATTN: Mr. Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

SUBJECT: DAIRYLAND POWER COOPERATIVE
LA CROSSE BOILING WATER REACTOR (LACBWR)
PROVISIONAL OPERATING LICENSE NO. DPR-45
APPLICATION FOR AMENDMENT TO LICENSE

Reference: (1) 10 CFR 50, Section 50.90
(2) 10 CFR 170, Section 170.22

Gentlemen:

In accordance with the provisions of Reference (1), an application to amend Provisional Operating License No. DPR-45 for the La Crosse Boiling Water Reactor is hereby filed with three (3) signed original applications, together with thirty-seven (37) copies.

This change has been determined to be a Class II Amendment being administrative in nature as defined in Reference (2), and a check for \$1,200.00 is enclosed to cover the fee.

The enclosed change consists of proposed revisions to the administrative section of the LACBWR Technical Specifications, reflecting changes in the Dairyland Power Cooperative management structure and the facility staff, and incorporating Standard Technical Specifications.

The proposed Section 6.0 submitted herein is complete. The majority of the present Section 3.0 has been incorporated into the proposed Section 6.0 in order to conform to Standard Technical Specifications. The remainder of the present Section 3.0, e.g., Section 3.14, is to be deleted for the following reasons:

Section 3.14.1 - The requirements for having and using written procedures is addressed in Section 6.8 of this submittal.

Section 3.14.2 - The requirement to have qualified personnel is addressed in Section 6.3 of this submittal.

Section 3.14.3 - The requirement for drills (training) is addressed in Section 6.4 of this submittal.

Section 3.14.4 - The requirement to have and use procedures for off-normal operations is addressed in Section 6.8 of this submittal.

Section 3.14.5 - The requirement of Shift Supervisor control of bypass keyswitches is contained in written, approved procedures used under the supervision of the Shift Supervisor.

Section 3.14.6 - This requirement of Shift Supervisor control of locked plant valves is contained in written, approved valve lineup lists or procedures, used under the supervision of the Shift Supervisor.

Section 3.14.7 - The requirements of the Plant Superintendent authorizing the bypassing of interlocks is contained in written procedures, approved by the Plant Superintendent.

Section 4.1 - General and Sections 4.1.1 and 4.1.2 are to be deleted for the following reasons:

Section 4.1.1 - This requirement is specified in Paragraph 2C(2) of Provisional Operating License No. DPR-45.

Section 4.1.2 - This requirement is contained in Table 6.2.2-1, Minimum Shift Crew Composition, contained herein.

Change Section 4.1.3:

4.1.3 During periods when the reactor is in Condition 3, 4, or 5, either Channel 1 or 2 of the Nuclear Instrumentation System shall be in operation and shall be monitored by the operator.

Delete the asterisk and attendant note on the bottom of page 28. This change removes the ambiguity of the definition of "shutdown" here and the definitions of shutdown on page 27x, in the Table of Operational Conditions.

Mr. Dennis M. Crutchfield, Chief
Operating Reactors Branch #5


LAC-7073
August 6, 1980

The information submitted in this application for license amendment has been reviewed by the LACBWR Committees as prescribed in Technical Specifications.

If there are any questions concerning this submittal, please contact us.

Very truly yours.

DAIRYLAND POWER COOPERATIVE




Frank Linder, General Manager

FL:HAT:af

cc: J. Keppler, Reg. Dir., NRC-DRO III

STATE OF WISCONSIN)
)
COUNTY OF LA CROSSE)

Personally came before me this 27th day of August, 1980, the above named ~~Frank Linder~~ ^{James W. Taylor}, to me known to be the person who executed the foregoing instrument and acknowledged the same.



Notary Public, La Crosse County,
Wisconsin.

My Commission Expires 2/26/84.