



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Jea

August 14, 1980

Docket No. 50-312

Mr. J. J. Mattimoe
Assistant General Manager and
Chief Engineer
Sacramento Municipal Utility District
6201 S Street
P. O. Box 15830
Sacramento, California 95813

Dear Mr. Mattimoe:

In our continuing generic review of bypass and reset of engineered safety features, we have identified the need for additional information. This information is identified in the enclosure.

It is requested that you respond to the enclosed request for additional information within 45 days of receipt of this letter.

Sincerely,

A handwritten signature in dark ink, appearing to read "Tom Novak".

Thomas M. Novak, Assistant Director
for Operating Reactors
Division of Licensing

Enclosure:
Request for Additional
Information

cc w/enclosure:
See next page

8009030 344

p

Sacramento Municipal Utility
District

cc w/enclosure(s):

David S. Kaplan, Secretary and
General Counsel
6201 S Street
P. O. Box 15830
Sacramento, California 95813

Sacramento County
Board of Supervisors
827 7th Street, Room 424
Sacramento, California 95814

Business and Municipal Department
Sacramento City-County Library
828 I Street
Sacramento, California 95814

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection Agency
Crysta Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Region IX Office
ATTN: EIS COORDINATOR
215 Fremont Street
San Francisco, California 94111

Mr. Robert B. Borsum
Eabcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

Thomas Dexter, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, NW
Washington, D. C. 20036

Herbert H. Brown, Esq.
Lawrence Coe Lanpher, Esq.
Hill, Christopher and Phillips, P. C.
1900 M St., NW
Washington, D. C. 20036

Helen Hubbard
P. O. Box 63
Sunol, California 94586

Christopher Ellison, Esq.
Dian Grueuich, Esq.
California Energy Commission
1111 Howe Avenue
Sacramento, California 95825

Ms. Eleanor Schwartz
California State Office
600 Pennsylvania Avenue, S.E., Rm. 201
Washington, D.C. 20003

Docketing and Service Section
Office of the Secretary
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Resident Inspector
P. O. Box 48
Fair Oaks, California 95628

Dr. Richard F. Cole
Atomic Safety and Licensing Board
Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Frederick J. Shon
Atomic Safety and Licensing Board
Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Elizabeth S. Bowers, Esq.
Chairman, Atomic Safety and
Licensing Board Panel
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Michael R. Eaton
Energy Issues Coordinator
Sierra Club Legislative Office
1107 9th St., Room 1020
Sacramento, CA 95814

Sacramento Municipal Utility
District

cc w/enclosure(s):

Atomic Safety and Licensing Board
Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Atomic Safety and Licensing Appeal
Board Panel
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

California Department of Health
ATTN: Chief, Environmental
Radiation Control Unit
Radiological Health Section
714 P Street, Room 498
Sacramento, California

RANCHO SECO

REQUEST FOR ADDITIONAL INFORMATION

BYPASS AND RESET OF
ENGINEERED SAFETY FEATURES

1. For the CVI system, describe the extent to which the input instrumentation channels (including sensors), logic, etc. have been qualified to withstand the environmental and seismic conditions that could be expected to exist at the point of installation during postulated accidents.
2. For the Control Room Isolation system describe the extent to which the input instrumentation channels (including sensors), logic, etc. have been qualified to withstand the environmental and seismic conditions that could be expected to exist at the point of installation during postulated accidents.
3. Referring to drawing E-203, sheet 64C, provide development drawings for switches BLPB-1 and BLPB-2 and for relays RPIV/OC and RPIV/RC.
4. Referring to drawing E-203, sheet 8, provide the following:
 - a. A description and drawings of the trigger circuitry for the SCR which drives the 86 relay.
 - b. Development drawing for the CS switch.
 - c. Development drawing for the 52 contacts.
5. Provide three copies of 6292-E7.01-56.