



Metropolitan Edison Company
Post Office Box 480
Middletown, Pennsylvania 17057
717 944-4041

Writer's Direct Dial Number

August 25, 1980
TLL 418

Office of Inspection and Enforcement
Attn: Mr. Boyce H. Grier, Director
Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Licensee Event Report 80-034/03L-0

Attached please find Licensee Event Report 80-034/03L-0 concerning the failure to restore the Fuel Handling Building ventilation to an operable status following an automatic shutdown by the fire protection system, on July 25, 1980.

This event was not a violation of any Limiting Condition of Operation in the Unit 2 Interim Recovery Technical Specifications. It is considered reportable, however, under Section 6.9.1.9(b), due to an inadvertant entry into the action statement of Section 3.9.1 2(a).


Sincerely,

/s/ G. K. Hovey

G. K. Hovey
Director, TMI-2

GKH:SDC:dad

Attachments

cc: John T. Collins


8009030349

S

Metropolitan Edison Company is a Member of the General Public Utilities System

A002
S111