Update Report - Previous Report Date 6/27/80

NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | ARAN02 (2) | 00-0000-00 (3) | 41111 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T

01 | REPORT SOURCE L (6) | 05000368 (7) | 080480 (8) | 082980 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During Mode 1 operation, while testing the Emergency Feedwater Pump
03 (2P7A) an overspeed trip occurred rendering 2P7A inoperable. The elec-
04 tric Emergency Feedwater pump and associated valves were verified oper-
05 able. This occurrence is similar to LER's 50-368/79-055, 79-072, 79-081,
06 79-104, 80-022, 80-030, and 80-036. Reportable per Tech Spec. 6.9.1.9.b.
07
08

09 SYSTEM CODE WR (11) | CAUSE CODE B (12) | CAUSE SUBCODE A (13) | COMPONENT CODE TURBIN (14) | COMP SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 050 | / | OCCURRENCE CODE 03 | REPORT TYPE X | — | REVISION NO. 1

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB N (24) | PRIME COMP SUPPLIER A (25) | COMPONENT MANUFACTURER T147 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Investigation did not reveal the cause for an overspeed trip. The hy-
11 draulic control oil system is suspected. 2P7A was successfully started
12 five times following the overspeed trip. The vendor has been contacted
13 and is working on this problem. 2P7A is being started every 24 hours to
14 verify operability.

FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) Power Ops. | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Control Room Indication

ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER Rex Pendergraft PHONE 501-968-2519

8009030417