(1-11)	LICENSEE EVENT REPORT
•	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 7 8	M A P P S 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 6 6 CAT 58
0 1 7 8	REPORT L 6 0 5 0 - 0 2 9 3 7 0 8 0 2 8 0 8 0 8 2 9 8 0 9
0 2	EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) At 2330 on August 2, 1980 the high water level isolation main steam line drain valve
0 3	(MO-220-1) did not isolate. Reactor was in shutdown at this time. The I&C lab
0 4	was asked to investigate.
0 5	
0 6	
0 7	
0 8 7 8	9 SYSTEM CAUSE CAUSE COMP. VALVE
0 9	S D 11 X 12 B 13 I N S T R U 14 S 15 E Z 16
	17 REPORT NUMBER 21 22 23 24 26 27 28 29 30 31 32
	ACTION FUTURE COMPONENT SUBMITTED FORM SUB. PRIME COMP. COMPONENT MANUFACTURER SUBMITTED FORM SUB. SUPPLIER MANUFACTURER M
	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) Investigation revealed a setpoint on a Yarway level switch was not correct. Re-
10	
11	calibration and adjustment of the Yarway was conducted.
1 2	
1 3	
7 8	9 80 METHOD OF
1 5	STATUS OF POWER OTHER STATUS OF DISCOVERY DESCRIPTION (32) G 28 0 0 0 0 29 N.A. A 31 Operational event 9 0 12 13 44 45 46
1 6 R	CONTENT CONTENT SELEASE OF RELEASE AMOUNT OF ACTIVITY (35) N.A. LOCATION OF RELEASE (36) N.A. LOCATION OF RELEASE (36) N.A. 44
17	PERSONNEL EXPOSURES NUMBER 11 12 13 N.A. N.A.
1 8	PERSONNEL INJURIES NUMBER O O O O O O O O O O O O O O O O O O O
7 8	SO 11 12 LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION N.A.
7 8	9 10 PUBLICITY ISSUED DESCRIPTION 45 8009030483 N.A. NRC USE ONLY NRC USE ONLY
7 8	9 10 68 69 80 5 NAME OF PREPARER G. G. Whitney PHONE: 617-746-7900