

POOR ORIGINAL

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

August 28, 1980

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-259 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE  
REPORT BPRO-50-259/8058

The enclosed report provides details concerning PS-1-81 A and B,  
turbine first stage pressure permissive, setpoints which drifted  
above technical specification. This report is submitted in accordance  
with Browns Ferry unit 1 Technical Specification 6.7.2.b.2.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. R. Calhoun  
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Director (40)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. Bill Lavalles  
Nuclear Safety Analysis Center  
Palo Alto, California 94303

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

A002  
S  
1/1