

UNITED STATES NUCLEAR REGULATORY COMMISSION

REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

AUG 1 4 1980

Docket No. 50-329 Docket No. 50-330

Consumers Power Company
ATTN: Mr. Stephen H. Howell
Vice President
1945 West Parnall Road
Jackson, MI 49201

Gentlemen:

Thank you for your interim report dated July 31, 1980, pursuant to 10 CFR 50.55(e) regarding Safe Shutdown Boration Capability. We will review your final report on this matter upon receipt.

Your cooperation with us is appreciated.

Sincerely,

Gaston Fiorelli, Chief Reactor Construction and Engineering Support Branch

cc: Director, RCI/II
Director, AEQD
Chief, OEB/MPA
IE Files

cc w/ltr dtd 7/31/80:
Central Files
PDR
Local PDR
NSIC
Ronald Callen, Michigan Public
Service Commission
Myron M. Cherry, Chicago



James W Cook
Vice President, Midland Project

General Offices: 1945 West Parnall Road, Jackson, Michigan J49201 • (517) 788-0640 July 31, 1980

Mr J G Keppler, Regional Director Office of Inspection and Enforcement US Nuclear Regulatory Commission Region III 799 Roosevelt Road Glen Ellyn, IL 60137

MIDLAND NUCLEAR PLANT
UNIT NO 1, DOCKET NO 50-329
UNIT NO 2, DOCKET NO 50-330
SAFE SHUTDOWN BORATION CAPABILITY
FILE: 0.4.9.36 UFI: 73*10*01 SERIAL: 8807

References: S H Howell letters to J G Keppler; Midland Nuclear Plant; Unit No 1, Docket No 50-329; Unit No 2, Docket No 50-330; Safe Shutdown Boration Capability;

- 1) Serial Howe-283-79; dated October 21, 1979
- 2) Serial Howe-308-79; dated December 6, 1979
- 3) Serial Howe-73-80; dated April 11, 1980

This letter, as were the referenced letters, is an interim 50.55(e) report regarding safe shutdown capability assuming a most restrictive core condition and the control rod of highest worth stuck out of the core.

The design criteria and the system details have been reviewed and agreed upon by CPCo, Bechtel and B&W.

Engineering and procurement activities to date are listed below:

- The system summary description has been reviewed and commented on by CPCo and B&W
- Bechtel has issued P&ID Drawing M-782, which is currently being reviewed by CPCo and B&W
- An order for two (2) 2300 gallon ASME Section III Class 2 Boric Acid Tanks (with redundant heaters) has been placed with Richard Engineering Company (RECO)
- 4. An order has been placed for two (2) ASME Section III Class 2 pumps for recirculation of the emergency boration tank contents.

System turnover to CPCo is presently scheduled for November 1982.

Dre 0000000

AUG 6 1980

GRE/ch

CC Director of Office of Inspection & Enforcement ATT Mr Victor Stello, USNRC (15)

Director, Office of Management Information & Program Control, USNRC (1)