

TIC

Georgia Power Company  
Post Office Box 4545  
Atlanta, Georgia 30302  
Telephone 404 522-6060

USNRC REGION II  
ATLANTA, GEORGIA



08/05 P2:02 Vogtle Project

Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202  
Telephone 205 870-6011

August 5, 1980

United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, GA 30303

Reference:  
RII: JPO  
50-424  
50-425

Attention: Mr. James P. O'Reilly

File: X7BC24  
Log: GM-663

Gentlemen:

The following is submitted in response to your letter dated April 4, 1980 concerning I.E. Bulletin 79-03A.

Georgia Power Company has not identified any welded SA-312 or A-312 piping that exceeds pressure design stresses of 85% of the maximum allowable stress at the design temperature. Westinghouse, our NSSS supplier, is still investigating this problem as applicable to equipment under their scope and has requested an extension to October 1, 1980 to respond to this bulletin.

Georgia Power Company will provide the additional information concerning this bulletin by October 1, 1980 if this is acceptable to you.

Very truly yours,

Doug Dutton  
Project General Manager

CWH:tp

xc: U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Division of Reactor Operations Inspection  
Washington, DC

M. D. Hunt - USNRC, Region II

OFFICIAL COPY

8009040 637

Q

Mr. James P. O'Reilly  
RII: JPO/50-424; 50-425  
August 5, 1980  
Page 2

xc: J. H. Miller, Jr.  
W. E. Ehrensperger  
F. G. Mitchell, Jr.  
R. J. Kelly  
R. E. Conway  
R. W. Staffa  
J. T. Beckham  
K. M. Gillespie  
C. W. Hayes  
E. D. Groover  
D. L. McCrary  
R. A. Thomas  
M. Z. Jeric  
J. L. Vota