



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TERA

August 12, 1980

Docket No. 50-29

Mr. James A. Kay
Senior Engineer - Licensing
Yankee Atomic Electric Company
25 Research Drive
Westborough, Massachusetts 01581

Dear Mr. Kay:

By letter dated February 23, 1980, you were requested to provide information regarding primary coolant system pressure isolation valves. The objective of this 10 CFR 50.54(f) letter was to identify those plants which have either or both of the valve configurations found in WASH-1400 (Event V) to be significant risk contributors to an intersystem LOCA which results in a core melt accident.

We have confirmed that the two specific Event V valve configurations do not exist at your facility. This is based upon the evaluation of your response to our February letter as well as the review of previously docketed information (Enclosure). Based on this, our activities regarding these valve configurations have been finalized for your facility.

In addition to these Event V valve configurations, we are continuing our efforts to review other configurations located at high pressure/low pressure system boundaries for their potential risk contribution to an intersystem LOCA which may result in a core melt accident. Therefore, further activity regarding the broader topic of intersystem LOCA's may be expected in the future.

Your time and effort in closing out the Event V portion of the intersystem LOCA concern are appreciated.

Sincerely,

Walter L. Paulson

for Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure and ccs:
See next page

8009050 497

P

Mr. James A. Kay

- 2 -

August 12, 1980

Enclosure:
Franklin Research Center Technical
Evaluation Report, "Primary Coolant
System Pressure Isolation Valves,"
dated July 21, 1980.

cc w/enclosure:
See next page

Mr. James A. Kay

- 3 -

August 12, 1980

cc w/enclosure:
Mr. James E. Tribble, President
Yankee Atomic Electric Company
25 Research Drive
Westborough, Massachusetts 01581

Greenfield Community College
1 College Drive
Greenfield, Massachusetts 01301

Chairman
Board of Selectmen
Town of Rowe
Rowe, Massachusetts 01367

Energy Facilities Siting Council
14th Floor
One Ashburton Place
Boston, Massachusetts 02108

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection
Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection
Agency
Region I Office
ATTN: EIS COORDINATOR
JFK Federal Building
Boston, Massachusetts 02203

Resident Inspector
Yankee Rowe Nuclear Power Station
c/o U.S. NRC
Post Office Box 28
Monroe Bridge, Massachusetts 01350