

M. J. [unclear]

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 25, 1975

Docket Nos. 50-296
50-270
and 50-287

Duke Power Company
ATTN: Mr. Austin C. Thies
Senior Vice President
422 South Church Street
Post Office Box 2178
Charlotte, North Carolina 28201


Gentlemen:

The Commission has issued the enclosed Amendment No. 7, Technical Specification Change No. 17 for License No. DPR-38; Amendment No. 7, Technical Specification Change No. 12 for License No. DPR-47; and Amendment No. 4, Technical Specification Change No. 4 for License No. DPR-55, for the Oconee Nuclear Station, Units 1, 2, and 3. These amendments are in response to your request dated December 31, 1974.

These amendments specify the number of pressure relief valves in the pressurizer and main steam line to be checked each surveillance period, a specification inadvertently omitted in a previous license amendment.

Copies of the related Safety Evaluation and the Federal Register Notice are also enclosed.

Sincerely,



Robert A. Purple, Chief
Operating Reactors Branch #1
Division of Reactor Licensing

Enclosures:

1. Amendment No. 7 to DPR-38
2. Amendment No. 7 to DPR-47
3. Amendment No. 4 to DPR-55
4. Safety Evaluation
5. Federal Register Notice

cc w/enclosures:
See next page



8009050

514
~~514~~

P

cc w/enclosures:
Mr. William L. Porter
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28201

Mr. Troy B. Conner
Conner, Hadlock & Knotts
1747 Pennsylvania Avenue, NW
Washington, D. C. 20006

Oconee Public Library
201 South Spring Street
Walhalla, South Carolina 29691

Honorable Reese A. Hubbard
County Supervisor of Oconee County
Walhalla, South Carolina 29621

cc w/enclosures & incoming:
Mr. Elmer Whitten
State Clearinghouse
Office of the Governor
Division of Administration
1295 Pendleton Street
4th Floor
Columbia, South Carolina 29201

Mr. Dave Hopkins
Environmental Protection Agency
1421 Peachtree Street, NE
Atlanta, Georgia 30309