



UNITED STATES  
ATOMIC ENERGY COMMISSION  
WASHINGTON, D.C. 20545

November 26, 1974

Docket Nos. 50-269  
50-270  
and 50-287

Duke Power Company  
ATTN: Mr. Austin C. Thies  
Senior Vice President  
422 South Church Street  
Post Office Box 2178  
Charlotte, North Carolina 28201

Gentlemen:

The Commission has issued the enclosed Amendment No. 6, Technical Specification Change No. 16 for License No. DPR-38; Amendment No. 6, Technical Specification Change No. 11 for License No. DPR-47; and Amendment No. 3, Technical Specification Change No. 3 for License No. DPR-55, for the Oconee Nuclear Station, Units 1, 2, and 3. These amendments are in response to your request dated September 20, 1974, and subsequent letters dated October 8, 1974, and October 31, 1974.

These amendments include the Technical Specification changes required for the second fuel cycle operation of Oconee Unit 1. The proposed Control Rod Withdrawal Limit For 4 Pump Operations (Figure 3.5.2-1A2) after  $250 \pm 5$  full power days of operation has not been included in this change since it does not conform to the Interim Acceptance Criteria for ECCS and your proposed Final Acceptance Criteria (Appendix K) Technical Specifications have not yet been approved.

Copies of the related Safety Evaluation and the Federal Register Notice are also enclosed.

Sincerely,

Robert A. Purple, Chief  
Operating Reactors Branch #1  
Directorate of Licensing

Enclosures:  
See next page

8009050

561

P

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

November 26, 1974

Enclosures:

1. Amendment No. 6 to DPR-38
2. Amendment No. 6 to DPR-47
3. Amendment No. 3 to DPR-55
4. Safety Evaluation
5. Federal Register Notice

cc w/enclosures:

Mr. William L. Porter  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28201

Mr. Troy B. Conner  
Conner, Hadlock & Knotts  
1747 Pennsylvania Avenue, NW.  
Washington, D.C. 20006

Honorable Reese A. Hubbard  
County Supervisor of Oconee County  
Walhalla, South Carolina 29621

Oconee County Library  
201 South Spring Street  
Walhalla, South Carolina 29691

cc w/enclosures & incoming:

Mr. Elmer Whitten  
State Clearinghouse  
Office of the Governor  
Division of Administration  
1205 Pendleton Street  
4th Floor  
Columbia, South Carolina 29201

Mr. Dave Hopkins  
Environmental Protection Agency  
1421 Peachtree Street, NE.  
Atlanta, Georgia 30309