



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ARKANSAS POWER & LIGHT COMPANY

DOCKET NO. 50-313

ARKANSAS NUCLEAR ONE - UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 13
License No. DPR-51

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Arkansas Power & Light Company (the licensee) dated March 3, 1976, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8009080 674

P

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment.
3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Dennis L. Ziemann
Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 16, 1976

ATTACHMENT TO LICENSE AMENDMENT NO. 13

FACILITY OPERATING LICENSE NO. DPR-51

DOCKET NO. 50-313

Replace existing pages 66a, 83 and 110a of the Technical Specifications contained in Appendix A to the license with the attached revised pages bearing the same numbers. The changed areas on the revised pages are reflected by a marginal line. Also, pages 66b and 110b are enclosed as a matter of convenience in updating the Technical Specifications. There are no changes on these pages.

3.11 EMERGENCY COOLING POND

Applicability

Applies to the emergency cooling pond.

Objective

To assure the availability of a sufficient supply of cooling water inventory in the emergency cooling pond.

Specification

- 3.11.1 The reactor shall not be taken critical unless the emergency cooling pond is operable with:
1. An average water depth \geq 3'0", and
 2. An average water temperature \leq 105F.
- 3.11.2 With the requirements of Specification 3.11.1 not satisfied, be in the hot shutdown condition within 6 hours and in the cold shutdown condition within the following 30 hours.

Bases

The requirements of Specification 3.11.1 provide for sufficient water inventory in the emergency cooling pond to mitigate within acceptable limits the effects of a DBA with a concurrent failure of the Dardanelle Reservoir. The minimum water depth takes into account (1) water loss from evaporation due to heat load and climatological conditions, (2) pond bottom irregularities and (3) suction pipe level at the pond. The minimum water depth and maximum water temperature correspond to conservative values used to determine pond response and assure the applicability of the calculational model for pond evaporation.

3.12 MISCELLANEOUS RADIOACTIVE MATERIALS SOURCES

Applicability

Applies to byproduct, source, and special nuclear radioactive material sources.

Objective

To assure that leakage from byproduct, source, and special nuclear radioactive material sources does not exceed allowable limits.

Specification

- 3.12.1 The source leakage test performed pursuant to Specification 4.14 shall be capable of detecting the presence of 0.005 μCi of radioactive material on the test sample. If the test reveals the presence of 0.005 μCi or more of removable contamination, it shall immediately be withdrawn from use, decontaminated, and repaired, or be disposed of in accordance with Commission regulations. Sealed sources are exempt from such leak tests when the source contains 100 μCi or less of beta and/or gamma emitting material or 10 μCi or less of alpha emitting material.
- 3.12.2 A complete inventory of licensed radioactive materials in possession shall be maintained current at all times.

4.4.1.2.5 Test Frequency

Local leak detection tests shall be performed at a frequency of at least each refueling period, but in no case at intervals greater than two years except that:

- (a) The equipment hatch and fuel transfer tube seals shall be additionally tested after each opening.
- (b) If a personnel hatch or emergency hatch door is opened when reactor building integrity is required, the affected door seal shall be tested. In addition, a pressure test shall be performed on the personnel and emergency hatches every six months.

4.4.1.3 Reactor Building Modifications

Any major modification or replacement of components affecting the reactor building integrity shall be followed by either an integrated leak rate test or a local leak test, as appropriate, and shall meet the acceptance criteria specified in 4.4.1.1 and 4.4.1.2 respectively.

4.4.1.4 Isolation Valve Functional Tests

Every three months, remotely operated reactor building isolation valves shall be stroked to the position required to fulfill their safety function unless such operation is not practical during plant operation. The latter valves shall be tested during each refueling period.

4.4.1.5 Visual Inspection

A visual examination of the accessible interior and exterior surfaces of the reactor building structure and its components shall be performed during each refueling shutdown and prior to any integrated leak test, to uncover any evidence of deterioration which may affect either the reactor building's structural integrity or leak-tightness. The discovery of any significant deterioration shall be accompanied by corrective actions in accord with acceptable procedures, nondestructive tests, and inspections, and local testing where practical prior to the conduct of any integrated leak test. Such repairs shall be reported as part of the test results.

Bases (1)

The reactor building is designed for an internal pressure of 59 psig and a steam-air mixture temperature of 285 F. Prior to initial operation, the reactor building will be strength tested at 115% of design pressure and leak rate tested at the design pressure. The reactor building will also be leak tested prior to initial operation at not less than 50% of

4.13 EMERGENCY COOLING POND

Applicability

Applies to the emergency cooling pond.

Objective

To verify the availability of a sufficient supply of cooling water inventory in the emergency cooling pond.

Specification

- 4.13.1 The emergency cooling pond shall be determined operable by verifying:
1. At least once per 24 hours that the average water depth is $\geq 3'0''$.
 2. At least once per 24 hours during the period from June 1 to September 30 that the average water temperature at the point of discharge from the pond is $\leq 105^{\circ}\text{F}$.
- 4.13.2 Soundings shall be made annually of the emergency cooling pond bottom to ensure that the required volume of water is available.

Bases

The requirements of Specification 4.13 provide for verification of a sufficient water inventory in the emergency cooling pond to handle a DBA with a concurrent failure of the Dardanelle Reservoir. This specification ensures that Specification 3.11.1 is met. Monitoring temperature only during the period June 1 to September 30 of each year ensures that, during the hot summer months, the pond temperature limit is not exceeded. During other periods of the year the pond temperature will not have the potential to reach temperatures near 105F.

4.14 RADIOACTIVE MATERIALS SOURCES SURVEILLANCE

Applicability

Applies to leakage testing of byproduct, source, and special nuclear radioactive material sources.

Objective

To assure that leakage from byproduct, source, and special nuclear radioactive material sources does not exceed allowable limits.

Specification

Tests for leakage and/or contamination shall be performed by the licensee or by other persons specifically authorized by the Commission or an agreement State, as follows:

1. Each sealed source, except startup sources subject to core flux, containing radioactive material, other than Hydrogen 3, with a half-life greater than 30 days and in any form other than gas shall be tested for leakage and/or contamination at intervals not to exceed six months.
2. The periodic leak test required does not apply to sealed sources that are stored and not being used. The sources excepted from this test shall be tested for leakage prior to any use or transfer to another user unless they have been leak tested within six months prior to the date of use or transfer. In the absence of a certificate from a transferor indicating that a test has been made within six months prior to the transfer, sealed sources shall not be put into use until tested.
3. Startup sources shall be leak tested prior to and following any repair or maintenance and before being subjected to core flux.