



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TIC

MAY 14 1980

Docket No. 50-341


The Detroit Edison Company  
ATTN: Mr. Edward Hines, Assistant  
Vice President and Manager  
Quality Assurance  
2000 Second Avenue  
Detroit, MI 48226

Gentlemen:

Enclosed is IE Bulletin No. 80-07, Supplement No. 1, which specifies the NRC offices that should receive written reports submitted in response to this Bulletin.

Should you have any questions regarding this Bulletin or the actions required by you, please contact this office.

Sincerely,

  
James G. Keppler  
Director

Enclosure: IE Bulletin No.  
80-07, Supplement No. 1

cc w/encl:  
Central Files  
Director, NRR/DPM  
Director, NRR/DOR  
PDR  
Local PDR  
NSIC  
TIC  
Ronald Callen, Michigan Public  
Service Commission  
Eugene B. Thomas, Jr.,  
Attorney

8009090029

SSINS No.: 6820  
Accession No.:  
8005050055

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

DUPLICATE

May 13, 1980

IE Bulletin No. 80-07  
Supplement No. 1

BWR JET PUMP ASSEMBLY FAILURE

C. Reporting Requirements

The information in Items A.3, and B.1, is requested under the provisions of 10 CFR 50.54(f). Accordingly, you are requested to provide within the time periods specified in these items, written statements of this information, signed under oath or affirmation.

These reports should be submitted to the Director of the appropriate NRC Regional Office and a copy should be forwarded to the NRC Office of Inspection and Enforcement, Division of Reactor Operations Inspection, Washington, D.C. 20555.

Approved by GAO, B180225 (R0072); clearance expires 7-31-80. Approval was given under a blanket clearance specifically for identified generic problems.

RECENTLY ISSUED  
IE BULLETINS

| Bulletin No. | Subject   | Date Issued | Issued To  |
|--------------|---|-------------|--|
| 80-13        | Cracking In Core Spray Spargers   | 5/12/80     | All BWR's with an OL   |
| 80-12        | Decay Heat Removal System Operability   | 5/9/80      | Each PWR with an OL  |
| 80-11        | Masonry Wall Design   | 5/8/80      | All power reactor facilities with an OL, except Trojan                                   |
| 80-10        | Contamination of Nonradioactive System and Resulting Potential for Unmonitored, Uncontrolled Release to Environment | 5/6/80      | All power reactor facilities with an OL or CP  |
| 80-09        | Hydramotor Actuator Deficiencies  | 4/17/80     | All power reactor operating facilities and holders of power reactor construction permits |
| 80-08        | Examination of Containment Liner Penetration Welds  | 4/7/80      | All power reactors with a CP and/or OL no later than April 7, 1980                       |
| 80-07        | BWR Jet Pump Assembly Failure   | 4/4/80      | All GE BWR-3 and BWR-4 facilities with an OL   |
| 80-06        | Engineered Safety Feature (ESF) Reset Controls  | 3/13/80     | All power reactor facilities with an OL  |
| 80-05        | Vacuum Condition Resulting In Damage To Chemical Volume Control System (CVCS) Holdup Tanks                          | 3/10/80     | All PWR power reactor facilities holding OLs and to those with a CP                      |
| 79-01B       | Environmental Qualification of Class IE Equipment   | 2/29/80     | All power reactor facilities with an OL  |
| 80-04        | Analysis of a PWR Main Steam Line Break With Continued Feedwater Addition   | 2/8/80      | All PWR reactor facilities holding OLs and to those nearing licensing                    |