

**PGE**



ATTACHMENT 1

Portland General Electric Company  
Trojan Nuclear Plant  
P.O. Box 439  
Rainier, Oregon 97048  
(503) 556-3713

August 29, 1980  
CPY-834-80

Mr. R. H. Engelken, Director  
U.S. Nuclear Regulatory Commission, Region V  
1990 North California Blvd.  
Walnut Creek, CA 94596

Dear Sir:

In accordance with the Trojan Plant Operating License, Appendix A, US NRC Technical Specifications, Paragraph 6.9.1.9.b, attached is Licensee Event Report No. 80-17, concerning a situation where the fan for the west containment spray pump room was inoperable as a result of a concrete core drilling operation.

Sincerely,

C. P. Yundt  
General Manager

*JCP*  
CPY/JCP:na  
Attachments

c: LER Distribution

8009100453